

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jefferson

Cartridge or Bag Filtration

Month/Year: 9/2024
A

System Name: Olallie Lake Resort ID#: 41 94426 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1				15.00		
2	↑					
3	off					
4						
5	↓					
6	✓					
on 7	13	24	11	15	0.22	Before filter 0.35
8	↑					
9						
10						
11						
12						
13						
14	off					
15						
16						
17						
on 18	↓					
19	14	25	11	15	0.25	Before filter 0.37
20						
21	↑					
22						
23						
24	off					
25						
26						
27	↓					
28						
29	Closed for the 2024 season					
30						
31						

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: Diane Whitfield SIGNATURE: <i>Diane Whitfield</i> DATE: 9/30/24 PHONE #: (503) 853-3481 CERT #:	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: A

System Name: Olallie Lake Resort

ID#: 41 94426

Month/Year: 9/2024

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	1.4	37.2							
2	1.5								
3	1.5								
4	1.5								
5	1.5								
6	1.4			60°F					
on (7)	1.4	37.2	52.08	17°C	6.95	23	yes		
8	1.4								
9	1.5								
10	1.5								
11	1.5								
12	1.5								
13	1.4								
14	1.4								
15	1.4								
16	1.4								
17	1.4								
18	1.4			50°F					
on (19)	1.4	37.2	52.08	10°C	7.07	41	yes		
20	1.4								
21	1.5								
22	1.5								
23	1.5								
24	1.5								
25	1.5								
26	1.4								
27	1.4								
28	1.4								
closing (29)	1.4	Closed for the 2024 Season							
30									
31									

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Reopen mid-June 2025 😊