

Cartridge or Bag Filtration

Month/Year:

6/2025

System Name:	Olallie Lake Resort	ID#:	41 94426	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1				15.00		
2	12	23	11	15.00	0.28	
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13	12	24	12	15.00	0.43	
14						
15						
16						
17						
18						
19						
20						
21	13	24	11	15.00	0.52	
22						
23						
24						
25						
26						
27						
28	13	24	11	15.00	0.31	
29						
30						
31						

Cartridge & Bag Filtration

95% of daily turbidity readings $\leq$ 1 NTU?

(Yes) / No

All daily turbidity readings $\leq$ 5 NTU?

(Yes) / No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

(Yes) / No

All Cl₂ residual at entry point $\geq$ 0.2
mg/l?

(Yes) / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's
specifications when to change the filter at what PSID.

PRINTED NAME: Diane Whitfield

SIGNATURE: Diane Whitfield

DATE: 7/2/25

PHONE #: (503) 853-3481

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-:

A

System Name:

Olallie Lake Resort

ID#: 41

94426

Month/Year:

6/2025

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
1		37.2		49°F				
2	1.7	37.2	63.24	10°C	7.10	43	yes	
3	1.7							
4	1.6							
5	1.6							
6	1.6							
7	1.5							
8	1.5							
9	1.4							
10	1.4							
11	1.4							
12	1.4			54°F				
13	1.2	37.2	44.64	12°C	7.01	34	yes	
14	1.2							
15	1.2							
16	1.5							
17	1.5							
18	1.5							
19	1.4							
20	1.4			52°F				
21	1.4	37.2	52.08	11°C	6.80	34	yes	
22	1.4							
23	1.4							
24	1.6							
25	1.6							
26	1.5							
27	1.5			53°F				
28	1.4	37.2	52.08	12°C	6.91	34	yes	
29	1.4							
30	1.5							
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013