

Cartridge or Bag Filtration

Month/Year:

7/2025

System Name:	Olallie Lake Resort		ID#:	41	94426	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]		
1				15.00				
2								
3								
4								
on 5	12	24	12	15.00	0.24			
6								
7								
8								
9								
10								
11								
on 12	12	24	12	15.00	0.20			
13								
14								
15								
16								
17								
18								
19								
20								
21								
on 22	11	24	13	15.00	0.18			
23								
24								
25								
26								
27								
on 28	12	24	12	15.00	0.17			
29								
30								
31								

Cartridge & Bag Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings $\leq$ 1 NTU?

(Yes) / No

CT's met everyday?
(see back)All Cl₂ residual at entry point $\geq$ 0.2 mg/l?All daily turbidity readings $\leq$ 5 NTU?

(Yes) / No

(Yes) / No

(Yes) / No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Diane Whitfield

SIGNATURE: *Diane Whitfield*

DATE: 8/3/25

PHONE #: (503) 853-3481

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-:

A

System Name:

Olallie Lake Resort

ID#: 41

94426

Month/Year:

7/2025

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.5	37.2						
2	1.5							
3	1.5							
4	1.4			56°F				
on (5)	1.4	37.2	52.08	13°C	6.79	29	yes	
6	1.4							
7	1.5							
8	1.5							
9	1.5							
10	1.5							
11	1.5			56°F				
on (12)	1.4	37.2	52.08	13°C	6.94	31	yes	
13	1.4							
14	1.4							
15	1.5							
16	1.5							
17	1.5							
18	1.5							
19	1.4							
20	1.4							
21	1.4			58°F				
on (22)	1.4	37.2	52.08	14°C	7.02	30	yes	
23	1.5							
24	1.6							
25	1.6							
26	1.5							
27	1.5			60°F				
on (28)	1.5	37.2	55.8	15°C	7.04	27	yes	
29	1.6							
30	1.6							
31	1.5							

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013