

Cartridge or Bag Filtration

Month/Year: 8/2025

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1				15.00		
2						
3						
on 4	13	25	12	15.00	0.17	
5						
6						
7						
8						
9						
10						
on 11	12	25	13	15.00	0.16	
12						
13						
14						
15						
16						
17						
on 18						
19	13	26	13	15.00	0.15	
20						
21						
22						
23						
24						
on 25						
26	13	25	12	15.00	0.20	
27						
28						
29						
30						
31						

Cartridge & Bag Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU?

(Yes / No)

CT's met everyday?
(see back)

All Cl2 residual at entry point ≥ 0.2 mg/l?

All daily turbidity readings ≤ 5 NTU?

(Yes / No)

(Yes / No)

(Yes / No)

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Dane Whitfield

SIGNATURE: Dane Whitfield DATE: 9/3/2025

PHONE #: (503) 853-3481

CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-:

A

System Name:

Olallie Lake Resort

ID#: 41

94426

Month/Year:

8/2025

Disinfection

Giardia Log

Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.4	37.2						
2	1.4							
3	1.4							
on ④	1.4	37.2	52.08	60°F 15°C	7.02	27.00	yes	
5	1.4							
6	1.5							
7	1.6							
8	1.6							
9	1.6							
10	1.5			58°F				
on ⑪	1.5	37.2	55.8	14°C	7.07	30.00	yes	
12	1.5							
13	1.5							
14	1.6							
15	1.5							
16	1.5							
17	1.5							
18	1.4			58°F				
on ⑲	1.4	37.2	52.08	14°C	6.80	27.00	yes	
20	1.4							
21	1.5							
22	1.6							
23	1.5							
24	1.5							
25	1.5			58°F				
on ⑳	1.5	37.2	55.8	14°C	6.71	27.00	yes	
27	1.5							
28	1.5							
29	1.4							
30	1.4							
31	1.4							

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013