

OHA - Drinking Water Services - Surface Water Quality Data Form

County:

Jefferson

Cartridge or Bag Filtration

Month/Year:

9/2025

System Name:	Olallie Lake Resort	ID#:	41	94426	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	↓ off			15.00			
2							
on (3)	13	25	12	15.00	0.14		
4							
5	↑			↑			
6	↓ off			↓ off			
7							
8							
9							
on (10)	12	25	13	15.00	0.22		
11							
12	↑			↑			
13	↓ off			↓ off			
14							
15	↓ off			↓ off			
16							
on (18)	12	25	13	15.00	0.19		
19							
20	↑			↑			
21							
22							
23							
24	off			off			
25							
26							
27							
X (28)	Closed for the 2025 Season						
29							
30							
31	↓			↓			

Cartridge & Bag Filtration

95% of daily turbidity readings ≤ 1 NTU?

(Yes / No)

All daily turbidity readings ≤ 5 NTU?

(Yes / No)

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)

(Yes / No)

All Cl2 residual at entry point ≥ 0.2
mg/l?

(Yes / No)

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = look in manual for manufacturer's
specifications when to change the filter, at what PSID.

PRINTED NAME: Diane Whitfield

SIGNATURE: *Diane Whitfield* DATE: 9/30/25

PHONE #: (503) 853-3481 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not
correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A

System Name: Olallie Lake Resort

ID#: 41 94426

Month/Year: 9/2025

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
1	1.4	37.2						
2	1.4							
3	1.4	37.2	52.08	60°F 15°C	6.71	24	yes	
4	1.5							
5	1.5							
6	1.5							
7	1.4							
8	1.4							
9	1.3			55°F				
10	1.3	37.2	48.36	13°C	6.81	30	yes	
11	1.4							
12	1.4							
13	1.5							
14	1.6							
15	1.6							
16	1.5							
17	1.5			52°F				
18	1.5	37.2	55.8	11°C	6.77	37	yes	
19	1.5							
20	1.6							
21	1.6							
22	1.5							
23	1.5							
24	1.5							
25	1.5							
26	1.5							
27	1.5							
28	1.5							
29	X	Closed 9/28/2025 for the Season						
30								
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

PAGE 2 of 2

Closed 9/28/2025