

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Mar-23**

System Name: **Whaleshead Resort & RV Park** ID#: **41-94489** WTP ID: **A** TP- **Lower**

| Day | PSI Before Filter | PSI After Filter | PSID | Change Filter ALERT (max is 30 psid) | Daily Turbidity Reading [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------------|------------------|------|---|-------------------------------|---|
| 1 | 10 | 10 | 0 | OK | 0.20 | |
| 2 | 10 | 10 | 0 | OK | 0.20 | |
| 3 | 10 | 10 | 0 | OK | 0.20 | |
| 4 | 11 | 10 | 1 | OK | 0.20 | |
| 5 | 11 | 10 | 1 | OK | 0.20 | |
| 6 | 11 | 10 | 1 | OK | 0.20 | |
| 7 | 11 | 10 | 1 | OK | 0.33 | |
| 8 | 11 | 10 | 1 | OK | 0.52 | |
| 9 | 11 | 10 | 1 | OK | 0.45 | |
| 10 | 12 | 10 | 2 | OK | 0.00 | |
| 11 | 12 | 10 | 2 | OK | 0.20 | |
| 12 | 12 | 10 | 2 | OK | 0.20 | |
| 13 | 12 | 10 | 2 | OK | 0.20 | |
| 14 | 12 | 10 | 2 | OK | 0.30 | |
| 15 | 13 | 10 | 3 | OK | 0.37 | |
| 16 | 14 | 10 | 4 | OK | 0.40 | |
| 17 | 14 | 10 | 4 | OK | 0.20 | |
| 18 | 14 | 10 | 4 | OK | 0.51 | |
| 19 | 15 | 10 | 5 | OK | 0.49 | |
| 20 | 15 | 10 | 5 | OK | 0.51 | |
| 21 | 16 | 10 | 6 | OK | 0.35 | |
| 22 | 16 | 10 | 6 | OK | 0.40 | |
| 23 | 16 | 10 | 6 | OK | 0.39 | |
| 24 | 17 | 10 | 7 | OK | 0.21 | |
| 25 | 17 | 10 | 7 | OK | 0.35 | |
| 26 | 17 | 10 | 7 | OK | 0.28 | |
| 27 | 13 | 10 | 3 | OK | 0.40 | |
| 28 | 13 | 10 | 3 | OK | 0.50 | |
| 29 | 13 | 10 | 3 | OK | 0.68 | |
| 30 | 13 | 10 | 3 | OK | 0.71 | |
| 31 | 13 | 10 | 3 | OK | 0.70 | |

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU?

Yes

CT's met everyday?
(see back)

Yes

All Cl₂ residual at entry point ≥ 0.2 mg/l?

Yes

All daily turbidity readings ≤ 5 NTU?

Yes

Notes:

PRINTED NAME: Dave Terrusa

SIGNATURE: /S/ Dave Terrusa

4/4/23

PHONE #: (541) 253-7556

CERT #: 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

This form Modified 10/3/2022

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

A

System Name: Whaleshead Resort & RV Park

ID#: 41-94489

Month/Year: Mar-23

Mar-23

Disinfection *Giardia*
Log Inactiv:

0.5

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ² | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² | Peak Hourly Demand Flow |
|---------------|---|------------------|--------------|-------|------|-------------|----------------------|-------------------------|
| Daily @ 09:00 | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.07 | 60 | 64.2 | 6.5 | 6.50 | 20.5 | YES | |
| 2 | 1.01 | 60 | 60.6 | 6.5 | 6.50 | 20.4 | YES | |
| 3 | 1.00 | 60 | 60.0 | 6.4 | 6.40 | 19.8 | YES | |
| 4 | 1.05 | 60 | 63.0 | 6.4 | 6.40 | 19.9 | YES | |
| 5 | 1.09 | 60 | 65.4 | 6.4 | 6.40 | 20.0 | YES | |
| 6 | 1.06 | 60 | 63.6 | 6.5 | 6.50 | 20.5 | YES | |
| 7 | 1.12 | 60 | 67.2 | 8.3 | 6.40 | 17.8 | YES | |
| 8 | 1.10 | 60 | 66.0 | 8.2 | 6.40 | 17.8 | YES | |
| 9 | 1.57 | 60 | 94.2 | 8.4 | 6.40 | 18.5 | YES | |
| 10 | 1.01 | 60 | 60.6 | 8.4 | 6.40 | 17.4 | YES | |
| 11 | 1.01 | 60 | 60.6 | 8.7 | 6.50 | 17.7 | YES | |
| 12 | 1.01 | 60 | 60.6 | 8.8 | 6.50 | 17.6 | YES | |
| 13 | 1.07 | 60 | 64.2 | 9.0 | 6.50 | 17.5 | YES | |
| 14 | 1.12 | 60 | 67.2 | 9.3 | 6.60 | 17.8 | YES | |
| 15 | 1.01 | 60 | 60.6 | 8.4 | 6.60 | 18.7 | YES | |
| 16 | 1.11 | 60 | 66.6 | 8.6 | 6.50 | 18.0 | YES | |
| 17 | 1.10 | 60 | 66.0 | 8.7 | 6.50 | 17.9 | YES | |
| 18 | 1.01 | 60 | 60.6 | 9.2 | 6.60 | 17.7 | YES | |
| 19 | 1.01 | 60 | 60.6 | 9.4 | 6.70 | 18.1 | YES | |
| 20 | 1.01 | 60 | 60.6 | 9.3 | 6.80 | 18.9 | YES | |
| 21 | 1.01 | 60 | 60.6 | 8.7 | 6.70 | 18.9 | YES | |
| 22 | 1.01 | 60 | 60.6 | 8.7 | 6.60 | 18.3 | YES | |
| 23 | 1.01 | 60 | 60.6 | 8.9 | 6.60 | 18.1 | YES | |
| 24 | 1.01 | 60 | 60.6 | 8.3 | 6.70 | 19.4 | YES | |
| 25 | 1.01 | 60 | 60.6 | 8.6 | 6.70 | 19.1 | YES | |
| 26 | 1.01 | 60 | 60.6 | 8.5 | 6.70 | 19.2 | YES | |
| 27 | 1.03 | 60 | 61.8 | 8.7 | 6.60 | 18.3 | YES | |
| 28 | 1.01 | 60 | 60.6 | 8.4 | 6.60 | 18.7 | YES | |
| 29 | 1.10 | 60 | 66.0 | 9.1 | 6.70 | 18.6 | YES | |
| 30 | 1.35 | 60 | 81.0 | 9.3 | 6.60 | 18.3 | YES | |
| 31 | 1.27 | 60 | 76.2 | 9.1 | 6.60 | 18.4 | YES | |

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 10/3/2022 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350