

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Jul-23**

System Name: **Whaleshead Resort & RV Park** ID#: **41-94489** WTP ID: **A** TP- **Lower**

| Day | PSI Before Filter | PSI After Filter | PSID | Change Filter ALERT (max is 30 psid) | Daily Turbidity Reading [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------------|------------------|------|--------------------------------------|-------------------------------|---|
| 1 | 18 | 10 | 8 | OK | 0.68 | |
| 2 | 18 | 10 | 8 | OK | 0.74 | |
| 3 | 18 | 10 | 8 | OK | 0.63 | |
| 4 | 18 | 10 | 8 | OK | 0.59 | |
| 5 | 18 | 10 | 8 | OK | 0.58 | |
| 6 | 18 | 10 | 8 | OK | 0.52 | |
| 7 | 19 | 10 | 9 | OK | 0.59 | |
| 8 | 19 | 10 | 9 | OK | 0.64 | |
| 9 | 20 | 10 | 10 | OK | 0.61 | |
| 10 | 20 | 10 | 10 | OK | 0.60 | |
| 11 | 20 | 10 | 10 | OK | 0.56 | |
| 12 | 22 | 10 | 12 | OK | 0.41 | |
| 13 | 22 | 10 | 12 | OK | 0.65 | |
| 14 | 22 | 10 | 12 | OK | 0.71 | |
| 15 | 23 | 10 | 13 | OK | 0.65 | |
| 16 | 23 | 10 | 13 | OK | 0.63 | |
| 17 | 23 | 10 | 13 | OK | 0.53 | |
| 18 | 23 | 10 | 13 | OK | 0.60 | |
| 19 | 23 | 10 | 13 | OK | 0.52 | |
| 20 | 24 | 10 | 14 | OK | 0.54 | |
| 21 | 24 | 10 | 14 | OK | 0.59 | |
| 22 | 24 | 10 | 14 | OK | 0.56 | |
| 23 | 24 | 10 | 14 | OK | 0.61 | |
| 24 | 25 | 10 | 15 | OK | 0.70 | |
| 25 | 25 | 10 | 15 | OK | 0.61 | |
| 26 | 25 | 10 | 15 | OK | 0.53 | |
| 27 | 26 | 10 | 16 | OK | 0.69 | |
| 28 | 26 | 10 | 16 | OK | 0.61 | |
| 29 | 26 | 10 | 16 | OK | 0.64 | |
| 30 | 26 | 10 | 16 | OK | 0.57 | |
| 31 | 26 | 10 | 16 | OK | 0.61 | |

| Monthly Summary (Answer Yes or No) | |
|---|--|
| 95% of daily turbidity readings ≤ 1 NTU? Yes | CT's met everyday? (see back) Yes |
| All daily turbidity readings ≤ 5 NTU? Yes | All Cl2 residual at entry point ≥ 0.2 mg/l? Yes |

| | | |
|---------------|------------------------------------|-----------------------|
| Notes: | PRINTED NAME: Dave Terrusa | |
| | SIGNATURE: /S/ Dave Terrusa | Date: 8/4/2023 |
| | PHONE #: (541) 253-7556 | CERT #: 6930 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **This form Modified 10/3/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

| | | | | | | |
|--------------|-----------------------------|---------------|-------------|--------|--|-----|
| System Name: | Whaleshead Resort & RV Park | ID#: 41-94489 | Month/Year: | Jul-23 | Disinfection <i>Giardia</i> Log Inactiv: | 0.5 |
|--------------|-----------------------------|---------------|-------------|--------|--|-----|

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ² | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² | Peak Hourly Demand Flow |
|---------------|---|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| Daily @ 09:00 | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.01 | 60 | 60.6 | 11.6 | 6.10 | 12.9 | YES | |
| 2 | 1.05 | 60 | 63.0 | 12.1 | 6.20 | 13.0 | YES | |
| 3 | 1.10 | 60 | 66.0 | 12.0 | 6.10 | 12.7 | YES | |
| 4 | 1.09 | 60 | 65.4 | 12.1 | 6.00 | 12.2 | YES | |
| 5 | 1.00 | 60 | 60.0 | 12.2 | 6.10 | 12.4 | YES | |
| 6 | 1.32 | 60 | 79.2 | 12.3 | 6.20 | 13.2 | YES | |
| 7 | 1.23 | 60 | 73.8 | 12.3 | 6.20 | 13.1 | YES | |
| 8 | 1.10 | 60 | 66.0 | 12.5 | 6.30 | 12.6 | YES | |
| 9 | 1.14 | 60 | 68.4 | 12.7 | 6.20 | 12.0 | YES | |
| 10 | 1.20 | 60 | 72.0 | 12.3 | 6.10 | 12.6 | YES | |
| 11 | 1.18 | 60 | 70.8 | 12.4 | 6.10 | 12.5 | YES | |
| 12 | 1.70 | 60 | 102.0 | 12.3 | 6.00 | 12.9 | YES | |
| 13 | 1.37 | 60 | 82.2 | 12.4 | 6.10 | 12.8 | YES | |
| 14 | 1.43 | 60 | 85.8 | 12.5 | 6.00 | 11.7 | YES | |
| 15 | 1.35 | 60 | 81.0 | 11.9 | 6.10 | 13.1 | YES | |
| 16 | 1.44 | 60 | 86.4 | 11.7 | 6.10 | 13.4 | YES | |
| 17 | 1.39 | 60 | 83.4 | 11.8 | 6.20 | 13.7 | YES | |
| 18 | 1.43 | 60 | 85.8 | 12.0 | 6.10 | 13.2 | YES | |
| 19 | 1.36 | 60 | 81.6 | 12.2 | 6.00 | 12.5 | YES | |
| 20 | 1.47 | 60 | 88.2 | 12.1 | 6.00 | 12.7 | YES | |
| 21 | 1.07 | 60 | 64.2 | 12.3 | 6.10 | 12.4 | YES | |
| 22 | 1.03 | 60 | 61.8 | 11.9 | 6.10 | 12.7 | YES | |
| 23 | 1.01 | 60 | 60.6 | 12.1 | 6.00 | 12.1 | YES | |
| 24 | 1.17 | 60 | 70.2 | 11.9 | 6.00 | 12.5 | YES | |
| 25 | 1.21 | 60 | 72.6 | 12.0 | 6.00 | 12.4 | YES | |
| 26 | 1.34 | 60 | 80.4 | 11.9 | 5.90 | 12.3 | YES | |
| 27 | 1.21 | 60 | 72.6 | 11.7 | 6.00 | 12.7 | YES | |
| 28 | 1.17 | 60 | 70.2 | 11.9 | 6.00 | 12.5 | YES | |
| 29 | 1.35 | 60 | 81.0 | 12.1 | 6.10 | 13.0 | YES | |
| 30 | 1.32 | 60 | 79.2 | 11.7 | 6.10 | 13.2 | YES | |
| 31 | 1.28 | 60 | 76.8 | 11.9 | 6.10 | 13.0 | YES | |

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 10/3/2022 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350