

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Feb-24**

System Name: Whaleshead Beach Resort		ID#: 41-94489		WTP ID: A		TP: Lower	
Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	14	11	3	OK	0.80		
2	14	11	3	OK	0.81		
3	14	11	3	OK	0.80		
4	14	11	3	OK	0.80		
5	14	11	3	OK	0.82		
6	15	11	4	OK	0.84		
7	15	11	4	OK	0.69		
8	15	11	4	OK	0.70		
9	15	11	4	OK	0.81		
10	16	11	5	OK	0.78		
11	16	11	5	OK	0.78		
12	16	11	5	OK	0.76		
13	16	11	5	OK	0.71		
14	16	11	5	OK	0.81		
15	16	11	5	OK	0.88		
16	16	11	5	OK	0.90		
17	17	11	6	OK	0.84		
18	17	11	6	OK	0.89		
19	18	11	7	OK	0.77		
20	18	11	7	OK	0.80		
21	18	11	7	OK	0.90		
22	18	11	7	OK	0.87		
23	18	11	7	OK	0.80		
24	18	11	7	OK	0.77		
25	19	11	8	OK	0.74		
26	19	11	8	OK	0.61		
27	19	11	8	OK	0.71		
28	19	11	8	OK	0.30		
29	19	11	8	OK	0.81		
30				Change Filter			
31				Change Filter			

Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: Dave Terrusa	
	SIGNATURE: /S/ Dave Terrusa	3/8/24
	PHONE #: (541) 253-7556	CERT #: 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

This form Modified 10/3/2022

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Whaleshead Beach Resort	ID#: 41-94489	Month/Year: Feb-24	Disinfection Giardia Log Inactiv:	0.5
---	----------------------	---------------------------	--	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.21	60	72.6	12.0	6.10	12.9	YES	22
2	1.17	60	70.2	11.9	6.10	12.9	YES	
3	1.08	60	64.8	11.8	6.00	12.4	YES	
4	1.09	60	65.4	11.9	6.00	12.4	YES	
5	1.17	60	70.2	11.7	6.00	12.6	YES	
6	1.23	60	73.8	11.8	6.10	13.0	YES	
7	1.43	60	85.8	11.8	6.10	13.3	YES	
8	1.17	60	70.2	11.7	6.20	13.5	YES	
9	1.31	60	78.6	11.7	6.20	13.7	YES	
10	1.30	60	78.0	11.8	6.10	13.1	YES	
11	1.28	60	76.8	11.9	6.10	13.0	YES	
12	1.24	60	74.4	11.9	6.20	13.4	YES	
13	1.14	60	68.4	11.8	6.10	12.9	YES	
14	1.01	60	60.6	11.9	6.00	12.3	YES	
15	1.12	60	67.2	11.8	5.90	12.1	YES	
16	1.23	60	73.8	11.7	5.90	12.3	YES	
17	1.20	60	72.0	11.9	6.00	12.5	YES	
18	1.18	60	70.8	11.6	6.10	13.1	YES	
19	1.26	60	75.6	11.8	6.00	12.7	YES	
20	1.09	60	65.4	11.9	5.90	12.0	YES	
21	1.12	60	67.2	11.8	5.90	12.1	YES	
22	1.18	60	70.8	11.9	6.00	12.5	YES	
23	1.23	60	73.8	12.0	6.00	12.5	YES	
24	1.18	60	70.8	12.0	6.10	12.8	YES	
25	1.24	60	74.4	11.8	6.00	12.6	YES	
26	1.12	60	67.2	12.0	6.10	12.7	YES	
27	1.07	60	64.2	11.9	6.20	13.2	YES	
28	1.13	60	67.8	11.8	6.20	13.3	YES	
29	1.20	60	72.0	11.7	6.30	14.0	YES	
30		60						
31		60						

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised 10/3/2022 PAX