

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Curry

Cartridge or Bag Filtration

Month/Year: May-24

System Name: Whaleshead Beach Resort LLC ID#: 41-94489 WTP ID: A-Lower Park

| Day | PSI Before Filter | PSI After Filter | PSID | Change Filter ALERT<br>(max is 30 psid) | Daily Turbidity Reading [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
|-----|-------------------|------------------|------|---|-------------------------------|---|
| 1   | 13                | 20               | -7   | OK                                      | 1.43                          |   |
| 2   | 8                 | 20               | -12  | OK                                      | 1.12                          |   |
| 3   | 5                 | 20               | -15  | OK                                      | 1.98                          |   |
| 4   | 5                 | 20               | -15  | OK                                      | 4.20                          |   |
| 5   | 5                 | 20               | -15  | OK                                      | 3.40                          |   |
| 6   | 5                 | 20               | -15  | OK                                      | 1.85                          |   |
| 7   | 5                 | 22               | -17  | OK                                      | 0.83                          |   |
| 8   | 6                 | 21               | -15  | OK                                      | 0.92                          |   |
| 9   | 6                 | 21               | -15  | OK                                      | 2.77                          |   |
| 10  | 6                 | 21               | -15  | OK                                      | 1.48                          |   |
| 11  | 8                 |                  | 8    | OK                                      | 2.07                          |   |
| 12  | 9                 | 23               | -14  | OK                                      | 1.80                          |   |
| 13  | 10                |                  | 10   | OK                                      | 2.30                          |   |
| 14  | 10                |                  | 10   | OK                                      | 1.31                          |   |
| 15  | 16                |                  | 16   | OK                                      | 1.72                          |   |
| 16  | 25                | 23               | 2    | OK                                      | 1.39                          |   |
| 17  | 3                 | 23               | -20  | OK                                      | 1.88                          |   |
| 18  | 5                 | 24               | -19  | OK                                      | 1.71                          |   |
| 19  | 5                 | 24               | -19  | OK                                      | 1.84                          |   |
| 20  | 11                | 24               | -13  | OK                                      | 1.47                          |   |
| 21  | 7                 | 0                | 7    | OK                                      | 1.21                          |   |
| 22  | 17                | 0                | 17   | OK                                      | 1.34                          |   |
| 23  | 20                | 0                | 20   | OK                                      | 1.12                          |   |
| 24  | 20                | 0                | 20   | OK                                      |                               |   |
| 25  | 2                 | 0                | 2    | OK                                      |                               |   |
| 26  | 4                 | 0                | 4    | OK                                      | 1.25                          |   |
| 27  | 24                | 0                | 24   | OK                                      | 1.02                          |   |
| 28  | 25                | 8                | 17   | OK                                      | 1.02                          |   |
| 29  | 25                | 8                | 17   | OK                                      | 1.00                          |   |
| 30  | 30                | 10               | 20   | OK                                      | 0.93                          |   |
| 31  | 5                 | 0                | 5    | OK                                      | 1.26                          |   |

| Cartridge & Bag Filtration                          | Monthly Summary (Answer Yes or No)       |  |
|---|--|--|
| 95% of daily turbidity readings ≤ 1 NTU? <b>Yes</b> | CT's met everyday? (see back) <b>Yes</b> | All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b> |
| All daily turbidity readings ≤ 5 NTU? <b>Yes</b>    |  |  |

|  |   |                             |
|--|---|-----------------------------|
| <b>Notes:</b> Plant turbidity readings exceeded the limit of 1 NTU everyday except for three. Upon further investigating, it seems that the turbidimeter needs to be calibrated or replaced. The operator was refreshed on the turbidity rule. The Tier II notice was delivered to customers. (BV) | <b>PRINTED NAME:</b> Brenda Vasquez       |                             |
|  | <b>SIGNATURE:</b> <i>Brenda L Vasquez</i> | 6/9/2024                    |
|  | <b>PHONE #:</b> (541) 254-1909            | <b>CERT#</b><br>T2D1-070226 |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **This form Modified 3/6/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A-Lower Park

|                     |                             |                      |                    |        |  |            |
|---------------------|-----------------------------|----------------------|--------------------|--------|--|------------|
| <b>System Name:</b> | Whaleshead Beach Resort LLC | <b>ID#:</b> 41-94489 | <b>Month/Year:</b> | May-24 | <b>Disinfection<br/>Giardia Log Inactiv:</b> | <b>0.5</b> |
|---------------------|-----------------------------|----------------------|--------------------|--------|--|------------|

| Date / Time   | Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup> | Contact Time (T) | Actual CT    | Temp  | pH   | Required CT | CT Met? <sup>2</sup> | Peak Hourly Demand Flow |
|---------------|---|------------------|--------------|-------|------|-------------|----------------------|-------------------------|
| Daily @ 09:00 | [ppm or mg/L]   | [minutes]        | <b>C X T</b> | [° C] |      | formula     | Yes / No             | [GPM]                   |
| 1             | 0.55  | 60               | 33.0         | 11.0  | 7.30 | 19.1        | YES                  | 25                      |
| 2             | 0.74  | 60               | 44.4         | 12.2  | 7.50 | 19.3        | YES                  |                         |
| 3             | 0.61  | 60               | 36.6         | 12.7  | 7.70 | 19.7        | YES                  |                         |
| 4             | 1.22  | 60               | 73.2         | 13.2  | 7.30 | 17.6        | YES                  |                         |
| 5             | 0.33  | 60               | 19.8         | 10.3  | 6.70 | 15.9        | YES                  |                         |
| 6             | 0.53  | 60               | 31.8         | 11.9  | 7.10 | 16.8        | YES                  |                         |
| 7             | 0.78  | 60               | 46.8         | 13.3  | 7.00 | 14.9        | YES                  |                         |
| 8             | 0.78  | 60               | 46.8         | 11.9  | 6.80 | 15.6        | YES                  |                         |
| 9             | 0.92  | 60               | 55.2         | 16.1  | 6.80 | 11.6        | YES                  |                         |
| 10            | 1.70  | 60               | 102.0        | 14.7  | 7.50 | 18.1        | YES                  |                         |
| 11            | 0.46  | 60               | 27.6         | 13.7  | 7.20 | 15.0        | YES                  |                         |
| 12            | 1.55  | 60               | 93.0         | 13.5  | 7.40 | 18.6        | YES                  |                         |
| 13            | 0.74  | 60               | 44.4         | 13.0  | 7.80 | 20.3        | YES                  |                         |
| 14            | 0.62  | 60               | 37.2         | 16.6  | 7.00 | 11.7        | YES                  |                         |
| 15            | 0.55  | 60               | 33.0         | 14.4  | 7.20 | 14.5        | YES                  |                         |
| 16            | 0.74  | 60               | 44.4         | 17.2  | 7.50 | 13.7        | YES                  |                         |
| 17            | 0.54  | 60               | 32.4         | 15.7  | 7.50 | 14.8        | YES                  |                         |
| 18            | 0.45  | 60               | 27.0         | 12.7  | 7.50 | 17.9        | YES                  |                         |
| 19            | 0.38  | 60               | 22.8         | 12.5  | 7.30 | 16.8        | YES                  |                         |
| 20            | 0.35  | 60               | 21.0         | 12.2  | 7.70 | 19.8        | YES                  |                         |
| 21            | 0.49  | 60               | 29.4         | 12.2  | 7.50 | 18.8        | YES                  |                         |
| 22            | 1.74  | 60               | 104.4        | 13.4  | 7.50 | 19.8        | YES                  |                         |
| 23            | 1.53  | 60               | 91.8         | 12.7  | 7.80 | 22.7        | YES                  |                         |
| 24            | 0.27  | 60               | 16.2         | 12.3  | 7.60 | 18.9        | NO                   |                         |
| 25            | 0.81  | 60               | 48.6         | 13.7  | 7.60 | 18.2        | YES                  |                         |
| 26            | 0.94  | 60               | 56.4         | 12.5  | 7.50 | 19.2        | YES                  |                         |
| 27            | 0.67  | 60               | 40.2         | 12.6  | 7.80 | 20.7        | YES                  |                         |
| 28            | 0.71  | 60               | 42.6         | 12.8  | 7.50 | 18.4        | YES                  |                         |
| 29            | 1.12  | 60               | 67.2         | 12.7  | 7.70 | 20.8        | YES                  |                         |
| 30            | 0.68  | 60               | 40.8         | 14.7  | 7.40 | 15.5        | YES                  |                         |
| 31            | 0.46  | 60               | 27.6         | 13.5  | 7.80 | 19.0        | YES                  |                         |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350