

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Curry

Cartridge or Bag Filtration

Month/Year: Jun-25

System Name: Whaleshead Beach Resort LLC		ID#: 41-94489	WTP ID: A-Lower Park			
Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	5	1	4	OK		0.21
2	5	1	4	OK		0.19
3	5	1	4	OK		0.16
4	6	1	5	OK		0.16
5	6	1	5	OK		0.17
6	6	1	5	OK		0.15
7	6	1	5	OK		0.17
8	6	1	5	OK		0.20
9	6	1	5	OK		0.17
10	8	1	7	OK		0.15
11	6	1	5	OK		0.16
12	6	1	5	OK		0.17
13	6	1	5	OK		0.19
14	6	1	5	OK		0.19
15	6	1	5	OK		0.19
16	6	1	5	OK		0.21
17	8	1	7	OK		0.17
18	8	1	7	OK		0.23
19	8	1	7	OK		0.17
20	9	1	8	OK		0.17
21	9	1	8	OK		0.20
22	10	1	9	OK		0.21
23	10	1	9	OK		0.13
24	10	1	9	OK		0.15
25	10	1	9	OK		0.16
26	10	1	9	OK		0.14
27	11	1	10	OK		0.17
28	11	1	10	OK		0.14
29	11	1	10	OK		0.16
30	11	1	10	OK		0.17
31				Change Filter		

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:		PRINTED NAME: Brenda Vasquez	
		SIGNATURE: Brenda L Vasquez	7/2/2025
		PHONE #: (541) 254-1909	CERT# T2D1-070226

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may notcorrespond to continuous readings' maximum. **This form Modified 3/6/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: A-Lower Park

System Name:	Whaleshead Beach Resort LLC	ID#: 41-94489	Month/Year:	Jun-25	Disinfection Giardia Log Inactiv:	0.5
---------------------	-----------------------------	----------------------	--------------------	--------	--	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.60	60	36.0	14.8	6.80	12.2	YES	25
2	0.55	60	33.0	14.7	6.75	12.0	YES	25
3	0.56	60	33.6	15.6	6.80	11.5	YES	25
4	0.60	60	36.0	15.4	6.88	12.1	YES	25
5	0.64	60	38.4	15.5	6.97	12.5	YES	25
6	0.54	60	32.4	15.5	6.87	11.9	YES	25
7	0.45	60	27.0	15.3	6.90	12.1	YES	25
8	0.41	60	24.6	15.2	6.99	12.5	YES	25
9	0.53	60	31.8	15.8	6.71	11.0	YES	25
10	0.58	60	34.8	15.4	6.67	11.2	YES	25
11	0.60	60	36.0	16.2	6.61	10.4	YES	25
12	0.67	60	40.2	15.9	6.61	10.7	YES	25
13	0.74	60	44.4	15.8	6.63	10.9	YES	25
14	0.91	60	54.6	15.9	6.77	11.6	YES	25
15	0.77	60	46.2	15.9	6.68	11.1	YES	25
16	0.67	60	40.2	17.2	6.83	10.6	YES	25
17	1.08	60	64.8	16.4	6.84	11.8	YES	25
18	1.12	60	67.2	17.2	6.96	11.7	YES	25
19	1.12	60	67.2	16.5	7.11	13.0	YES	25
20	1.08	60	64.8	16.6	6.94	12.1	YES	25
21	1.11	60	66.6	16.4	6.62	10.9	YES	25
22	1.18	60	70.8	16.5	6.71	11.3	YES	25
23	1.06	60	63.6	19.8	6.95	9.7	YES	25
24	1.05	60	63.0	19.0	6.88	10.0	YES	25
25	0.95	60	57.0	18.8	6.78	9.7	YES	25
26	1.02	60	61.2	19.4	6.84	9.6	YES	25
27	1.19	60	71.4	19.0	6.78	9.8	YES	25
28	0.97	60	58.2	19.4	6.84	9.5	YES	25
29	1.02	60	61.2	20.4	6.55	8.0	YES	25
30	0.74	60	44.4	20.6	6.52	7.6	YES	25
31		60						25

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX