

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Curry

Cartridge or Bag Filtration

Month/Year: Nov-25

System Name: Whaleshead Beach Resort LLC ID#: 41 94489 WTP ID: TP- A-Lower Park

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	15.00	1.00	14.00	OK	0.14	0.14
2	15.00	1.00	14.00	OK	0.15	0.15
3	15.00	1.00	14.00	OK	0.20	0.20
4	16.00	1.00	15.00	OK	0.14	0.14
5	16.00	1.00	15.00	OK	0.18	0.18
6	17.00	1.00	16.00	OK	0.13	0.13
7	17.00	1.00	16.00	OK	0.19	0.19
8	14.00	1.00	13.00	OK	0.25	0.25
9	13.00	1.00	12.00	OK	0.18	0.18
10	12.00	1.00	11.00	OK	0.20	0.20
11	12.00	1.00	11.00	OK	0.18	0.18
12	11.00	1.00	10.00	OK	0.20	0.20
13	11.00	1.00	10.00	OK	0.18	0.18
14	11.00	1.00	10.00	OK	0.15	0.15
15	11.00	1.00	10.00	OK	0.16	0.16
16	11.00	1.00	10.00	OK	0.13	0.13
17	12.00	1.00	11.00	OK	0.17	0.17
18	14.00	1.00	13.00	OK	0.19	0.19
19	14.00	1.00	13.00	OK	0.19	0.19
20	16.00	1.00	15.00	OK	0.13	0.13
21	16.00	1.00	15.00	OK	0.20	0.20
22	15.00	1.00	14.00	OK	0.22	0.22
23	15.00	1.00	14.00	OK	0.25	0.25
24	14.00	1.00	13.00	OK	0.16	0.16
25	14.00	1.00	13.00	OK	0.15	0.15
26	14.00	1.00	13.00	OK	0.19	0.19
27	14.00	1.00	13.00	OK	0.24	0.24
28	15.00	1.00	14.00	OK	0.18	0.18
29	15.00	1.00	14.00	OK	0.14	0.14
30	16.00	1.00	15.00	OK	0.23	0.23
31		1.00		Change Filter		

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Giovanni Rangel	
	SIGNATURE: <i>Giovanni Rangel</i>	DATE: 12/09/2025
	PHONE #: (541) 373-9150	CERT #: T1D1-859079

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : -Lower Par

System Name: Whaleshead Beach Resort LLC	ID#: 41	94489	Month/Year: Nov-25	Disinfection <i>Giardia</i> Log Inactiv: 1
--	---------	-------	--------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.51	60	30.6	13.1	6.64	25.6	YES	25
2	0.65	60	39.0	12.9	6.69	26.8	YES	25
3	0.71	60	42.6	13.6	6.70	25.9	YES	25
4	0.69	60	41.4	13.8	6.61	24.6	YES	25
5	0.85	60	51.0	14.9	6.71	24.2	YES	25
6	0.82	60	49.2	13.8	6.65	25.4	YES	25
7	0.9	60	54.0	14.4	6.55	23.7	YES	25
8	1.19	60	71.4	13.5	6.68	27.3	YES	25
9	0.98	60	58.8	13.8	6.39	23.5	YES	25
10	0.69	60	41.4	14.1	6.61	24.1	YES	25
11	1.95	60	117.0	14.1	6.65	28.3	YES	25
12	1.8	60	108.0	14.3	6.78	28.8	YES	25
13	0.4	60	24.0	14.1	6.63	23.5	YES	25
14	0.85	60	51.0	13.8	6.78	26.7	YES	25
15	0.91	60	54.6	13.5	6.69	26.6	YES	25
16	0.64	60	38.4	13.6	6.74	26.1	YES	25
17	0.56	60	33.6	13.3	6.71	26.1	YES	25
18	0.65	60	39.0	12.4	6.67	28.5	YES	25
19	0.66	60	39.6	12.0	6.69	29.5	YES	25
20	0.88	60	52.8	12.4	6.62	28.7	YES	25
21	0.84	60	50.4	13.6	6.60	25.3	YES	25
22	0.62	60	37.2	12.1	6.66	28.9	YES	25
23	0.73	60	43.8	11.6	6.64	29.9	YES	25
24	0.73	60	43.8	10.7	6.66	31.9	YES	25
25	1.6	60	96.0	9.9	6.69	37.3	YES	25
26	0.88	60	52.8	11.8	6.78	31.5	YES	25
27	0.58	60	34.8	12.1	6.78	29.9	YES	25
28	0.95	60	57.0	12.4	6.82	31.0	YES	25
29	0.65	60	39.0	12.2	6.88	31.0	YES	25
30	0.68	60	40.8	12.2	6.91	31.4	YES	25
31		60						25

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350