

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Jul-21**

System Name: Whaleshead RV Park & Resort			ID#: 41-94489	WTP ID: B		TP- Upper
Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	15	8	7	OK	0.85	
2	15	8	7	OK	0.86	
3	16	8	8	OK	0.72	
4	17	9	8	OK	0.70	
5	20	10	10	OK	0.82	
6	22	11	11	OK	0.75	
7	22	12	10	OK	0.70	
8	22	12	10	OK	0.52	
9	25	12	13	OK	0.63	
10	15	8	7	OK	0.73	
11	17	9	8	OK	0.89	
12	17	9	8	OK	0.73	
13	17	9	8	OK	0.64	
14	17	9	8	OK	0.57	
15	18	10	8	OK	0.62	
16	19	10	9	OK	0.75	
17	19	10	9	OK	0.67	
18	21	11	10	OK	0.58	
19	21	11	10	OK	0.63	
20	22	11	11	OK	0.51	
21	25	11	14	OK	0.59	
22	22	11	11	OK	0.75	
23	22	11	11	OK	0.63	
24	27	11	16	OK	0.51	
25	28	11	17	OK	0.50	
26	29	11	18	OK	0.63	
27	29	11	18	OK	0.60	
28	30	11	19	OK	0.50	
29	22	11	11	OK	0.48	
30	22	11	11	OK	0.31	
31	22	11	11	OK	0.50	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes	Yes	Yes
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID. (30 psi Harmsco)		PRINTED NAME: Dave Terrusa SIGNATURE: /S/ Dave Terrusa 9/7/2021 PHONE #: (541) 253-7556 CERT #: 6930	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum. **This form Modified 7/4/2020**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

B

System Name:

Whaleshead RV Park & Resort

ID#: 41-94489

Month/Year:

Aug-21

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.44	132	190.1	14.9	6.50	12.0	YES	
2	1.30	132	171.6	15.9	6.40	10.6	YES	
3	1.33	132	175.6	15.0	6.50	11.7	YES	
4	1.40	132	184.8	15.6	6.50	11.4	YES	
5	1.21	132	159.7	15.5	6.50	11.2	YES	
6	1.17	132	154.4	15.7	6.60	11.4	YES	
7	1.10	132	145.2	15.9	6.50	10.8	YES	
8	1.10	132	145.2	15.9	6.30	10.0	YES	
9	1.17	132	154.4	15.8	6.40	10.5	YES	
10	1.12	132	147.8	15.8	6.50	10.9	YES	
11	1.07	132	141.2	16.3	6.60	10.8	YES	
12	1.00	132	132.0	16.2	6.70	11.2	YES	
13	1.19	132	157.1	16.9	6.80	11.4	YES	
14	1.12	132	147.8	15.9	6.90	12.5	YES	
15	1.27	132	167.6	16.4	6.90	12.3	YES	
16	1.43	132	188.8	16.7	7.00	12.8	YES	
17	1.54	132	203.3	16.9	7.10	13.2	YES	
18	1.41	132	186.1	16.5	7.10	13.4	YES	
19	1.30	132	171.6	16.8	7.10	13.0	YES	
20	1.17	132	154.4	16.5	7.10	13.0	YES	
21	1.11	132	146.5	16.5	7.10	12.9	YES	
22	1.00	132	132.0	15.3	7.10	13.9	YES	
23	1.11	132	146.5	16.4	7.10	13.0	YES	
24	1.30	132	171.6	15.8	7.10	13.9	YES	
25	1.20	132	158.4	15.6	7.10	13.9	YES	
26	1.53	132	202.0	15.1	7.10	14.9	YES	
27	1.48	132	195.4	16.2	7.10	13.8	YES	
28	1.62	132	213.8	16.0	7.10	14.2	YES	
29	1.27	132	167.6	15.9	7.10	13.7	YES	
30	1.11	132	146.5	16.6	7.10	12.9	YES	
31	1.07	132	141.2	16.8	7.10	12.6	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 7/4/2020 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350