

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Oct-22**

System Name: Whaleshead RV Park & Resort		ID#: 41-94489		WTP ID: B		TP- Upper	
Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	13	10	3	OK	0.50		
2	13	10	3	OK	0.25		
3	13	10	3	OK	0.31		
4	13	10	3	OK	0.28		
5	14	10	4	OK	0.35		
6	14	10	4	OK	0.32		
7	14	10	4	OK	0.29		
8	15	10	5	OK	0.21		
9	15	10	5	OK	0.43		
10	16	10	6	OK	0.69		
11	17	10	7	OK	0.71		
12	18	10	8	OK	0.79		
13	18	10	8	OK	0.63		
14	19	10	9	OK	0.30		
15	19	10	9	OK	0.31		
16	20	10	10	OK	0.19		
17	20	10	10	OK	0.20		
18	20	10	10	OK	0.20		
19	21	10	11	OK	0.20		
20	21	10	11	OK	0.19		
21	22	10	12	OK	0.21		
22	22	10	12	OK	0.20		
23	22	10	12	OK	0.20		
24	23	10	13	OK	0.20		
25	23	10	13	OK	0.20		
26	23	10	13	OK	0.20		
27	24	10	14	OK	0.20		
28	24	10	14	OK	0.20		
29	24	10	14	OK	0.20		
30	24	10	14	OK	0.20		
31	24	10	14	OK	0.20		

95% of daily turbidity readings $\leq$ 1 NTU? Yes All daily turbidity readings $\leq$ 5 NTU? Yes				Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes All Cl2 residual at entry point $\geq$ 0.2 mg/l? Yes	
Notes:				PRINTED NAME: Dave Terrusa	
				SIGNATURE: /S/ Dave Terrusa 11/2/2022	
				PHONE #: (541) 253-7556 CERT #: 6930	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum. **This form Modified 3/6/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

B

System Name:

Whaleshead RV Park & Resort

ID#: 41-94489

Month/Year:

Oct-22

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.95	132	257.4	14.3	6.70	14.2	YES	
2	1.01	132	133.3	14.3	6.70	12.8	YES	
3	1.01	132	133.3	13.9	6.70	13.1	YES	
4	1.05	132	138.6	13.9	6.70	13.2	YES	
5	1.01	132	133.3	13.5	6.60	13.0	YES	
6	1.09	132	143.9	13.7	6.50	12.5	YES	
7	1.01	132	133.3	13.5	6.50	12.5	YES	
8	1.01	132	133.3	13.5	6.70	13.5	YES	
9	1.01	132	133.3	13.5	6.60	13.0	YES	
10	1.07	132	141.2	13.6	6.60	13.0	YES	
11	1.09	132	143.9	13.5	6.70	13.6	YES	
12	1.11	132	146.5	13.5	6.70	13.6	YES	
13	1.17	132	154.4	13.3	6.60	13.4	YES	
14	1.95	132	257.4	13.0	6.60	15.0	YES	
15	1.89	132	249.5	12.9	6.70	15.5	YES	
16	1.95	132	257.4	13.5	6.60	14.5	YES	
17	1.72	132	227.0	13.5	6.60	14.1	YES	
18	1.61	132	212.5	13.0	6.50	13.9	YES	
19	1.43	132	188.8	13.3	6.60	13.8	YES	
20	1.21	132	159.7	13.5	6.50	12.8	YES	
21	1.07	132	141.2	13.9	6.50	12.3	YES	
22	1.75	132	231.0	13.5	6.60	14.1	YES	
23	1.95	132	257.4	10.9	6.70	18.2	YES	
24	1.07	132	141.2	13.3	6.50	12.8	YES	
25	1.10	132	145.2	12.9	6.50	13.2	YES	
26	1.39	132	183.5	13.6	6.60	13.5	YES	
27	1.28	132	169.0	13.4	6.60	13.5	YES	
28	1.09	132	143.9	13.4	6.70	13.7	YES	
29	1.95	132	257.4	13.3	6.70	15.2	YES	
30	1.01	132	133.3	12.7	6.60	13.7	YES	
31	1.03	132	136.0	12.6	6.50	13.3	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350