

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Dec-22**

System Name: **Whaleshead RV Park & Resort** ID#: **41-94489** WTP ID: **B** TP- **Upper**

| Day | PSI Before Filter | PSI After Filter | PSID | Change Filter ALERT (max is 30 psid) | Daily Turbidity Reading [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------------|------------------|------|---|-------------------------------|---|
| 1 | 13 | 10 | 3 | OK | 0.20 | |
| 2 | 13 | 10 | 3 | OK | 0.20 | |
| 3 | 13 | 10 | 3 | OK | 0.20 | |
| 4 | 13 | 10 | 3 | OK | 0.20 | |
| 5 | 13 | 10 | 3 | OK | 0.20 | |
| 6 | 13 | 10 | 3 | OK | 0.20 | |
| 7 | 13 | 10 | 3 | OK | 0.20 | |
| 8 | 13 | 10 | 3 | OK | 0.20 | |
| 9 | 13 | 10 | 3 | OK | 0.20 | |
| 10 | 13 | 10 | 3 | OK | 0.20 | |
| 11 | 13 | 10 | 3 | OK | 0.20 | |
| 12 | 13 | 10 | 3 | OK | 0.20 | |
| 13 | 14 | 10 | 4 | OK | 0.20 | |
| 14 | 14 | 10 | 4 | OK | 0.20 | |
| 15 | 14 | 10 | 4 | OK | 0.20 | |
| 16 | 14 | 10 | 4 | OK | 0.20 | |
| 17 | 15 | 10 | 5 | OK | 0.20 | |
| 18 | 15 | 10 | 5 | OK | 0.20 | |
| 19 | 15 | 10 | 5 | OK | 0.20 | |
| 20 | 16 | 10 | 6 | OK | 0.20 | |
| 21 | 17 | 10 | 7 | OK | 0.20 | |
| 22 | 17 | 10 | 7 | OK | 0.20 | |
| 23 | 17 | 10 | 7 | OK | 0.20 | |
| 24 | 17 | 10 | 7 | OK | 0.20 | |
| 25 | 17 | 10 | 7 | OK | 0.20 | |
| 26 | 17 | 10 | 7 | OK | 0.20 | |
| 27 | 17 | 10 | 7 | OK | 0.20 | |
| 28 | 17 | 10 | 7 | OK | 0.20 | |
| 29 | 17 | 10 | 7 | OK | 0.20 | |
| 30 | 17 | 10 | 7 | OK | 0.20 | |
| 31 | 17 | 10 | 7 | OK | 0.20 | |

| | | | |
|---|--|---|--|
| 95% of daily turbidity readings ≤ 1 NTU? Yes All daily turbidity readings ≤ 5 NTU? Yes | | Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes All Cl2 residual at entry point ≥ 0.2 mg/l? Yes | |
|---|--|---|--|

| | | |
|--------|------------------------------------|---------------------|
| Notes: | PRINTED NAME: Dave Terrusa | |
| | SIGNATURE: /S/ Dave Terrusa | 1/3/2023 |
| | PHONE #: (541) 253-7556 | CERT #: 6930 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **This form Modified 3/6/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

B

| | | | | | | |
|---------------------|--|----------------------|--------------------|---------------|--|------------|
| System Name: | Whaleshead RV Park & Resort | ID#: 41-94489 | Month/Year: | Dec-22 | Disinfection Giardia Log Inactiv: | 0.5 |
|---------------------|--|----------------------|--------------------|---------------|--|------------|

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ² | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² | Peak Hourly Demand Flow |
|---------------|---|---------------------|-----------|-------|------|-------------|----------------------|----------------------------------|
| Daily @ 09:00 | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.01 | 132 | 133.3 | 10.4 | 6.60 | 16.4 | YES | |
| 2 | 1.31 | 132 | 172.9 | 10.5 | 6.60 | 16.9 | YES | |
| 3 | 1.03 | 132 | 136.0 | 9.8 | 6.70 | 17.7 | YES | |
| 4 | 1.80 | 132 | 237.6 | 9.3 | 6.70 | 19.9 | YES | |
| 5 | 1.80 | 132 | 237.6 | 9.5 | 6.80 | 20.3 | YES | |
| 6 | 1.95 | 132 | 257.4 | 9.8 | 6.70 | 19.6 | YES | |
| 7 | 1.75 | 132 | 231.0 | 9.8 | 6.80 | 19.8 | YES | |
| 8 | 1.75 | 132 | 231.0 | 10.0 | 6.90 | 20.3 | YES | |
| 9 | 1.20 | 132 | 158.4 | 10.5 | 6.80 | 17.8 | YES | |
| 10 | 1.01 | 132 | 133.3 | 10.3 | 6.80 | 17.7 | YES | |
| 11 | 1.01 | 132 | 133.3 | 9.2 | 6.70 | 18.3 | YES | |
| 12 | 1.03 | 132 | 136.0 | 9.4 | 6.70 | 18.1 | YES | |
| 13 | 1.01 | 132 | 133.3 | 9.1 | 6.80 | 19.1 | YES | |
| 14 | 1.01 | 132 | 133.3 | 9.3 | 6.80 | 18.9 | YES | |
| 15 | 1.01 | 132 | 133.3 | 9.1 | 6.70 | 18.5 | YES | |
| 16 | 1.01 | 132 | 133.3 | 9.0 | 6.70 | 18.6 | YES | |
| 17 | 1.01 | 132 | 133.3 | 9.1 | 6.70 | 18.5 | YES | |
| 18 | 1.48 | 132 | 195.4 | 9.1 | 6.70 | 19.5 | YES | |
| 19 | 1.43 | 132 | 188.8 | 9.6 | 6.60 | 18.1 | YES | |
| 20 | 1.31 | 132 | 172.9 | 9.4 | 6.70 | 18.7 | YES | |
| 21 | 1.27 | 132 | 167.6 | 10.1 | 6.60 | 17.2 | YES | |
| 22 | 1.20 | 132 | 158.4 | 9.3 | 6.50 | 17.4 | YES | |
| 23 | 1.26 | 132 | 166.3 | 9.5 | 6.50 | 17.3 | YES | |
| 24 | 1.21 | 132 | 159.7 | 9.6 | 6.40 | 16.5 | YES | |
| 25 | 1.17 | 132 | 154.4 | 9.6 | 6.40 | 16.4 | YES | |
| 26 | 1.21 | 132 | 159.7 | 9.4 | 6.50 | 17.3 | YES | |
| 27 | 1.17 | 132 | 154.4 | 9.7 | 6.50 | 16.9 | YES | |
| 28 | 1.23 | 132 | 162.4 | 9.0 | 6.60 | 18.4 | YES | |
| 29 | 1.01 | 132 | 133.3 | 9.1 | 6.50 | 17.2 | YES | |
| 30 | 1.01 | 132 | 133.3 | 9.1 | 6.50 | 17.2 | YES | |
| 31 | 1.01 | 132 | 133.3 | 9.6 | 6.50 | 16.7 | YES | |

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350