

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Apr-23**

System Name: **Whaleshead RV Park & Resort** ID#: **41-94489** WTP ID: **B** TP- **Upper**

Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	16	10	6	OK	0.20	
2	16	10	6	OK	0.20	
3	16	10	6	OK	0.20	
4	16	10	6	OK	0.20	
5	17	10	7	OK	0.20	
6	17	10	7	OK	0.20	
7	17	10	7	OK	0.20	
8	17	10	7	OK	0.57	
9	18	10	8	OK	0.20	
10	19	10	9	OK	0.20	
11	20	10	10	OK	0.20	
12	21	10	11	OK	0.20	
13	22	10	12	OK	0.30	
14	22	10	12	OK	0.38	
15	22	10	12	OK	0.20	
16	23	10	13	OK	0.20	
17	24	10	14	OK	0.20	
18	24	10	14	OK	0.20	
19	25	10	15	OK	0.37	
20	25	10	15	OK	0.41	
21	25	10	15	OK	0.59	
22	26	10	16	OK	0.51	
23	26	10	16	OK	0.46	
24	26	10	16	OK	0.69	
25	26	10	16	OK	0.46	
26	26	10	16	OK	0.37	
27	27	10	17	OK	0.25	
28	27	10	17	OK	0.33	
29	28	10	18	OK	0.41	
30	28	10	18	OK	0.60	
31		10		Change Filter	0.30	

		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: Dave Terrusa	
	SIGNATURE: /S/ Dave Terrusa	
	PHONE #: (541) 253-7556	CERT #: 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. *This form Modified 3/6/2022*

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : B

System Name:	Whaleshead RV Park & Resort	ID#: 41-94489	Month/Year:	Mar-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	-----------------------------	---------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.04	132	137.3	10.4	6.70	17.0	YES	
2	1.06	132	139.9	9.8	6.60	17.1	YES	
3	1.07	132	141.2	9.9	6.60	17.1	YES	
4	1.12	132	147.8	9.6	6.00	14.3	YES	
5	1.00	132	132.0	10.0	6.50	16.3	YES	
6	1.13	132	149.2	9.5	6.40	16.5	YES	
7	1.11	132	146.5	9.4	6.50	17.1	YES	
8	1.08	132	142.6	9.4	6.50	17.0	YES	
9	1.04	132	137.3	9.3	6.60	17.7	YES	
10	1.11	132	146.5	9.2	6.50	17.3	YES	
11	1.09	132	143.9	9.9	6.40	16.0	YES	
12	1.11	132	146.5	9.7	6.50	16.8	YES	
13	1.01	132	133.3	9.5	6.40	16.2	YES	
14	1.09	132	143.9	9.8	6.50	16.6	YES	
15	1.15	132	151.8	9.8	6.60	17.3	YES	
16	1.10	132	145.2	9.6	6.50	16.9	YES	
17	1.17	132	154.4	9.3	6.60	17.9	YES	
18	1.11	132	146.5	9.2	6.50	17.3	YES	
19	1.09	132	143.9	9.1	6.40	16.8	YES	
20	1.13	132	149.2	10.0	6.40	15.9	YES	
21	1.15	132	151.8	9.8	6.50	16.7	YES	
22	1.21	132	159.7	9.9	6.60	17.3	YES	
23	1.17	132	154.4	9.9	6.60	17.2	YES	
24	1.09	132	143.9	9.9	6.50	16.5	YES	
25	1.11	132	146.5	9.8	6.40	16.1	YES	
26	1.07	132	141.2	9.9	6.40	15.9	YES	
27	1.09	132	143.9	10.1	6.50	16.3	YES	
28	1.08	132	142.6	10.4	6.50	16.0	YES	
29	1.10	132	145.2	10.6	6.60	16.4	YES	
30	1.07	132	141.2	10.4	6.50	16.0	YES	
31	1.35	132	178.2	1.0		4.4	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350