

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Jul-23**

System Name: **Whaleshead RV Park & Resort** ID#: **41-94489** WTP ID: **B** TP- **Upper**

Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	15	10	5	OK	0.70	
2	15	10	5	OK	0.73	
3	15	10	5	OK	0.71	
4	15	10	5	OK	0.63	
5	15	10	5	OK	0.64	
6	16	10	6	OK	0.63	
7	16	10	6	OK	0.56	
8	16	10	6	OK	0.54	
9	17	10	7	OK	0.61	
10	17	10	7	OK	0.60	
11	18	10	8	OK	0.61	
12	18	10	8	OK	0.59	
13	19	10	9	OK	0.63	
14	19	10	9	OK	0.68	
15	19	10	9	OK	0.58	
16	19	10	9	OK	0.51	
17	20	10	10	OK	0.62	
18	20	10	10	OK	0.71	
19	21	10	11	OK	0.73	
20	21	10	11	OK	0.61	
21	21	10	11	OK	0.53	
22	21	10	11	OK	0.57	
23	21	10	11	OK	0.58	
24	22	10	12	OK	0.60	
25	22	10	12	OK	0.51	
26	23	10	13	OK	0.63	
27	24	10	14	OK	0.69	
28	24	10	14	OK	0.70	
29	24	10	14	OK	0.67	
30	24	10	14	OK	0.71	
31	25	10	15	OK	0.75	

95% of daily turbidity readings ≤ 1 NTU? Yes		Monthly Summary (Answer Yes or No)	
All daily turbidity readings ≤ 5 NTU? Yes		CT's met everyday? (see back) Yes	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes
Notes:		PRINTED NAME: Dave Terrusa	
		SIGNATURE: /S/ Dave Terrusa	08/04/23
		PHONE #: (541) 253-7556	CERT #: 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : B

System Name: Whaleshead RV Park & Resort	ID#: 41-94489	Month/Year: Jul-23	Disinfection Giardia Log Inactiv:	0.5
---	----------------------	---------------------------	--	------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.24	132	163.7	11.4	6.10	13.4	YES	
2	1.40	132	184.8	11.6	6.20	13.9	YES	
3	1.38	132	182.2	11.7	6.20	13.8	YES	
4	1.21	132	159.7	12.1	6.30	13.6	YES	
5	1.17	132	154.4	12.2	6.20	13.1	YES	
6	1.11	132	146.5	12.3	6.10	12.5	YES	
7	1.53	132	202.0	12.6	6.10	12.2	YES	
8	1.21	132	159.7	12.3	6.20	13.0	YES	
9	1.17	132	154.4	12.1	6.20	13.1	YES	
10	1.12	132	147.8	12.2	6.10	12.6	YES	
11	1.14	132	150.5	12.1	6.00	12.3	YES	
12	1.69	132	223.1	12.6	6.10	12.4	YES	
13	1.09	132	143.9	12.5	6.00	11.2	YES	
14	1.12	132	147.8	12.3	6.10	12.5	YES	
15	1.23	132	162.4	12.1	6.10	12.8	YES	
16	1.20	132	158.4	12.0	6.00	12.4	YES	
17	1.29	132	170.3	12.2	6.10	12.8	YES	
18	1.40	132	184.8	12.4	6.10	12.8	YES	
19	1.43	132	188.8	12.5	6.00	11.7	YES	
20	1.53	132	202.0	12.4	6.00	12.6	YES	
21	1.27	132	167.6	12.2	6.10	12.8	YES	
22	1.04	132	137.3	12.6	6.10	11.5	YES	
23	1.45	132	191.4	12.8	6.20	12.3	YES	
24	1.07	132	141.2	11.9	6.10	12.7	YES	
25	1.12	132	147.8	11.9	6.00	12.4	YES	
26	1.09	132	143.9	11.7	5.90	12.1	YES	
27	1.02	132	134.6	11.6	6.00	12.5	YES	
28	1.09	132	143.9	11.9	6.00	12.4	YES	
29	1.03	132	136.0	11.8	6.10	12.8	YES	
30	1.14	132	150.5	11.9	6.10	12.8	YES	
31	1.06	132	139.9	11.7	6.00	12.5	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX