

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Aug-23**

System Name: **Whaleshead RV Park & Resort** ID#: **41-94489** WTP ID: **B** TP- **Upper**

| Day | PSI Before Filter | PSI After Filter | PSID | Change Filter ALERT (max is 30 psid) | Daily Turbidity Reading [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------------|------------------|------|---|-------------------------------|---|
| 1 | 16 | 10 | 6 | OK | 0.71 | |
| 2 | 16 | 10 | 6 | OK | 0.73 | |
| 3 | 16 | 10 | 6 | OK | 0.63 | |
| 4 | 17 | 10 | 7 | OK | 0.81 | |
| 5 | 17 | 10 | 7 | OK | 0.78 | |
| 6 | 17 | 10 | 7 | OK | 0.74 | |
| 7 | 18 | 10 | 8 | OK | 0.70 | |
| 8 | 18 | 10 | 8 | OK | 0.65 | |
| 9 | 18 | 10 | 8 | OK | 0.50 | |
| 10 | 19 | 10 | 9 | OK | 0.53 | |
| 11 | 19 | 10 | 9 | OK | 0.61 | |
| 12 | 19 | 10 | 9 | OK | 0.64 | |
| 13 | 19 | 10 | 9 | OK | 0.60 | |
| 14 | 19 | 10 | 9 | OK | 0.53 | |
| 15 | 20 | 10 | 10 | OK | 0.69 | |
| 16 | 21 | 10 | 11 | OK | 0.81 | |
| 17 | 21 | 10 | 11 | OK | 0.71 | |
| 18 | 22 | 10 | 12 | OK | 0.70 | |
| 19 | 22 | 10 | 12 | OK | 0.76 | |
| 20 | 22 | 10 | 12 | OK | 0.73 | |
| 21 | 12 | 10 | 2 | OK | 0.70 | |
| 22 | 12 | 10 | 2 | OK | 0.79 | |
| 23 | 13 | 10 | 3 | OK | 0.70 | |
| 24 | 13 | 10 | 3 | OK | 0.61 | |
| 25 | 14 | 10 | 4 | OK | 0.71 | |
| 26 | 14 | 10 | 4 | OK | 0.69 | |
| 27 | 14 | 10 | 4 | OK | 0.70 | |
| 28 | 14 | 10 | 4 | OK | 0.63 | |
| 29 | 14 | 10 | 4 | OK | 0.61 | |
| 30 | 14 | 10 | 4 | OK | 0.68 | |
| 31 | 14 | 10 | 4 | OK | 0.79 | |

| | | | |
|---|--|---|--|
| 95% of daily turbidity readings ≤ 1 NTU? Yes | | Monthly Summary (Answer Yes or No) | |
| All daily turbidity readings ≤ 5 NTU? Yes | | CT's met everyday? (see back) Yes | All Cl2 residual at entry point ≥ 0.2 mg/l? Yes |
| Notes: | | PRINTED NAME: Dave Terrusa | |
| | | SIGNATURE: /S/ Dave Terrusa | 09/05/23 |
| | | PHONE #: (541) 253-7556 | CERT #: 6930 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **This form Modified 3/6/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : B

| | | | |
|---|----------------------|---------------------------|--|
| System Name: Whaleshead RV Park & Resort | ID#: 41-94489 | Month/Year: Aug-23 | Disinfection Giardia Log Inactiv: 0.5 |
|---|----------------------|---------------------------|--|

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ² | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² | Peak Hourly Demand Flow |
|---------------|---|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| Daily @ 09:00 | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.07 | 132 | 141.2 | 11.7 | 6.00 | 12.5 | YES | |
| 2 | 1.12 | 132 | 147.8 | 11.9 | 6.00 | 12.4 | YES | |
| 3 | 1.15 | 132 | 151.8 | 11.9 | 6.10 | 12.9 | YES | |
| 4 | 1.19 | 132 | 157.1 | 12.0 | 6.10 | 12.8 | YES | |
| 5 | 1.21 | 132 | 159.7 | 12.0 | 6.10 | 12.9 | YES | |
| 6 | 1.12 | 132 | 147.8 | 11.8 | 6.00 | 12.5 | YES | |
| 7 | 1.13 | 132 | 149.2 | 11.7 | 6.00 | 12.6 | YES | |
| 8 | 1.09 | 132 | 143.9 | 12.1 | 6.10 | 12.6 | YES | |
| 9 | 1.11 | 132 | 146.5 | 12.2 | 6.20 | 13.0 | YES | |
| 10 | 1.08 | 132 | 142.6 | 12.4 | 6.10 | 12.4 | YES | |
| 11 | 1.17 | 132 | 154.4 | 12.3 | 6.00 | 12.2 | YES | |
| 12 | 1.24 | 132 | 163.7 | 12.1 | 6.00 | 12.4 | YES | |
| 13 | 1.18 | 132 | 155.8 | 11.8 | 6.10 | 13.0 | YES | |
| 14 | 1.21 | 132 | 159.7 | 11.7 | 6.10 | 13.1 | YES | |
| 15 | 1.23 | 132 | 162.4 | 11.9 | 6.00 | 12.5 | YES | |
| 16 | 1.17 | 132 | 154.4 | 12.0 | 6.10 | 12.8 | YES | |
| 17 | 1.20 | 132 | 158.4 | 12.2 | 6.10 | 12.7 | YES | |
| 18 | 1.17 | 132 | 154.4 | 12.3 | 6.00 | 12.2 | YES | |
| 19 | 1.01 | 132 | 133.3 | 12.2 | 6.00 | 12.0 | YES | |
| 20 | 1.07 | 132 | 141.2 | 12.6 | 6.10 | 11.5 | YES | |
| 21 | 1.00 | 132 | 132.0 | 12.5 | 6.10 | 11.5 | YES | |
| 22 | 1.13 | 132 | 149.2 | 12.7 | 6.20 | 12.0 | YES | |
| 23 | 1.19 | 132 | 157.1 | 12.5 | 6.10 | 11.8 | YES | |
| 24 | 1.09 | 132 | 143.9 | 12.1 | 6.10 | 12.6 | YES | |
| 25 | 1.17 | 132 | 154.4 | 12.4 | 6.00 | 12.1 | YES | |
| 26 | 1.01 | 132 | 133.3 | 12.1 | 6.10 | 12.5 | YES | |
| 27 | 1.01 | 132 | 133.3 | 11.9 | 6.10 | 12.7 | YES | |
| 28 | 1.11 | 132 | 146.5 | 11.8 | 6.20 | 13.3 | YES | |
| 29 | 1.09 | 132 | 143.9 | 12.4 | 6.10 | 12.4 | YES | |
| 30 | 1.10 | 132 | 145.2 | 12.5 | 6.00 | 11.2 | YES | |
| 31 | 1.17 | 132 | 154.4 | 12.4 | 5.90 | 11.7 | YES | |

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX