

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Sep-23**

System Name: **Whaleshead RV Park & Resort** ID#: **41-94489** WTP ID: **B** TP- **Upper**

Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	13	10	3	OK	0.81	
2	13	10	3	OK	0.72	
3	13	10	3	OK	0.68	
4	14	10	4	OK	0.60	
5	14	10	4	OK	0.73	
6	14	10	4	OK	0.81	
7	14	10	4	OK	0.84	
8	15	11	4	OK	0.72	
9	15	11	4	OK	0.76	
10	15	11	4	OK	0.74	
11	16	11	5	OK	0.84	
12	16	11	5	OK	0.80	
13	16	11	5	OK	0.81	
14	17	11	6	OK	0.80	
15	17	11	6	OK	0.84	
16	17	11	6	OK	0.81	
17	17	11	6	OK	0.79	
18	18	11	7	OK	0.70	
19	18	11	7	OK	0.61	
20	18	11	7	OK	0.72	
21	18	11	7	OK	0.70	
22	18	11	7	OK	0.81	
23	18	11	7	OK	0.83	
24	18	11	7	OK	0.78	
25	18	11	7	OK	0.70	
26	18	11	7	OK	0.79	
27	19	11	8	OK	0.81	
28	19	11	8	OK	0.80	
29	19	11	8	OK	0.88	
30	19	11	8	OK	0.85	
31				Change Filter		

		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?	<b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
<b>Notes:</b>		<b>PRINTED NAME: Dave Terrusa</b>	
		<b>SIGNATURE: /S/ Dave Terrusa</b>	<b>10/09/23</b>
		<b>PHONE #: ( 541 ) 253-7556</b>	<b>CERT #: 6930</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **This form Modified 3/6/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : **B**

System Name: **Whaleshead RV Park & Resort**

ID#: **41-94489**

Month/Year: **Sep-23**

Disinfection  
*Giardia* Log Inactiv: **0.5**

**0.5**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	1.17	132	154.4	12.0	6.00	12.4	YES	
2	1.01	132	133.3	12.9	6.10	11.2	YES	
3	1.09	132	143.9	12.6	6.00	11.1	YES	
4	1.08	132	142.6	12.5	6.00	11.2	YES	
5	1.11	132	146.5	12.2	6.10	12.6	YES	
6	1.23	132	162.4	12.3	6.10	12.6	YES	
7	1.14	132	150.5	11.9	6.00	12.4	YES	
8	1.21	132	159.7	11.8	6.00	12.6	YES	
9	1.12	132	147.8	12.1	6.10	12.7	YES	
10	1.08	132	142.6	12.4	6.10	12.4	YES	
11	1.01	132	133.3	12.5	6.20	12.0	YES	
12	1.09	132	143.9	12.6	6.20	12.0	YES	
13	1.12	132	147.8	12.5	6.20	12.1	YES	
14	1.09	132	143.9	12.5	6.10	11.6	YES	
15	1.13	132	149.2	12.8	6.10	11.5	YES	
16	1.23	132	162.4	12.6	6.20	12.2	YES	
17	1.18	132	155.8	12.5	6.10	11.8	YES	
18	1.23	132	162.4	12.3	6.00	12.2	YES	
19	1.28	132	169.0	12.4	5.90	11.9	YES	
20	1.20	132	158.4	12.3	5.90	11.8	YES	
21	1.19	132	157.1	12.4	6.00	12.1	YES	
22	1.23	132	162.4	12.4	6.00	12.2	YES	
23	1.31	132	172.9	12.5	6.10	11.9	YES	
24	1.18	132	155.8	12.3	6.10	12.6	YES	
25	1.11	132	146.5	12.3	6.00	12.1	YES	
26	1.23	132	162.4	12.4	6.10	12.6	YES	
27	1.10	132	145.2	12.2	6.00	12.2	YES	
28	1.19	132	157.1	12.4	6.00	12.1	YES	
29	1.24	132	163.7	12.3	5.90	11.9	YES	
30	1.38	132	182.2	12.6	6.00	11.5	YES	
31		132						

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX