

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Curry**

Cartridge or Bag Filtration

Month/Year: **Feb-24**

System Name: **Whaleshead Beach Resort** ID#: **41-94489** WTP ID: **B** TP- **Upper**

Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	Comments
1	24	11	13	OK	0.80		
2	24	11	13	OK	0.84		
3	24	11	13	OK	0.81		
4	24	11	13	OK	0.78		
5	24	11	13	OK	0.81		
6	25	11	14	OK	0.86		
7	25	11	14	OK	0.81		
8	25	11	14	OK	0.80		
9	25	11	14	OK	0.81		
10	25	11	14	OK	0.84		
11	26	11	15	OK	0.87		
12	26	11	15	OK	0.80		
13	26	11	15	OK	0.79		
14	26	11	15	OK	0.80		
15	26	11	15	OK	0.87		
16	26	11	15	OK	0.90		
17	12	10	2	OK	0.84		Filter changed
18	12	10	2	OK	0.86		
19	12	10	2	OK	0.81		
20	12	10	2	OK	0.89		
21	13	10	3	OK	0.90		
22	13	10	3	OK	0.88		
23	13	10	3	OK	0.82		
24	13	10	3	OK	0.80		
25	13	10	3	OK	0.77		
26	14	10	4	OK	0.70		
27	14	10	4	OK	0.71		
28	14	10	4	OK	0.72		
29	14	10	4	OK	0.80		
30				Change Filter			
31				Change Filter			

Cartridge & Bag Filtration			Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes	

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID. (30 psi Harmsco)

PRINTED NAME: Dave Terrusa	
SIGNATURE: /S/ Dave Terrusa	Date: 03/08/24
PHONE #: (541) 253-7556	CERT #: 6930

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **This form Modified 12/07/2023 PAX**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: B Upper

System Name:	Whaleshead RV Park & Resort	ID#: 41-94489	Month/Year:	Feb-24	Disinfection Giardia Log Inactiv:	0.5
--------------	-----------------------------	---------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.30	132	171.6	12.0	6.10	13.0	YES	25
2	1.25	132	165.0	11.9	6.00	12.6	YES	
3	1.15	132	151.8	11.9	6.10	12.9	YES	
4	1.23	132	162.4	11.7	6.00	12.7	YES	
5	1.44	132	190.1	11.9	6.00	12.8	YES	
6	1.23	132	162.4	11.9	6.10	13.0	YES	
7	1.17	132	154.4	11.8	6.10	13.0	YES	
8	1.20	132	158.4	11.7	6.20	13.5	YES	
9	1.37	132	180.8	11.8	6.20	13.7	YES	
10	1.19	132	157.1	11.6	6.10	13.1	YES	
11	1.24	132	163.7	11.8	6.10	13.1	YES	
12	1.38	132	182.2	11.9	6.20	13.6	YES	
13	1.43	132	188.8	11.8	6.10	13.3	YES	
14	1.31	132	172.9	12.0	6.00	12.6	YES	
15	1.37	132	180.8	11.7	5.90	12.5	YES	
16	1.27	132	167.6	11.6	5.90	12.4	YES	
17	1.19	132	157.1	11.8	6.00	12.6	YES	
18	1.24	132	163.7	11.6	6.10	13.2	YES	
19	1.37	132	180.8	11.9	6.00	12.7	YES	
20	1.42	132	187.4	12.0	5.90	12.3	YES	
21	1.21	132	159.7	11.9	5.90	12.1	YES	
22	1.26	132	166.3	12.1	6.00	12.4	YES	
23	1.33	132	175.6	12.0	6.00	12.6	YES	
24	1.24	132	163.7	12.0	6.10	12.9	YES	
25	1.21	132	159.7	11.9	6.00	12.5	YES	
26	1.27	132	167.6	11.7	6.10	13.2	YES	
27	1.43	132	188.8	11.9	6.20	13.7	YES	
28	1.28	132	169.0	11.8	6.20	13.5	YES	
29	1.37	132	180.8	12.0	6.10	13.1	YES	
30		132						
31		132						

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 12/07/2023 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350