

OHA - Drinking Water Services - Surface Water Quality Data Form



County: Curry

Cartridge or Bag Filtration

Month/Year: May-24

System Name: Whaleshead Beach Resort LLC ID#: 41-94489 WTP ID: B-Upper Park

Day	PSI Before Filter	PSI After Filter	PSID	Change Filter ALERT (max is 30 psid)	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	20	8	12	OK	0.57	
2	20	8	12	OK	0.22	
3	22	8	14	OK	0.22	
4	30	8	22	OK	2.44	
5	30	8	22	OK	1.85	
6	30	8	22	OK	0.92	
7	30	8	22	OK	0.36	
8	26	8	18	OK	0.58	
9	25	8	17	OK	0.67	
10	25	8	17	OK	0.85	
11	26	8	18	OK	0.71	
12	31	8	23	OK	0.82	
13	29	8	21	OK	1.16	
14	30	8	22	OK	0.84	
15	30	8	22	OK	0.94	
16	31	8	23	OK	0.80	
17	55	8	47	Change Filter	0.44	
18	49	8	41	Change Filter	0.68	
19	26	8	18	OK	0.72	
20	30	8	22	OK	0.68	
21	25	0	25	OK	0.74	
22	25	0	25	OK	0.88	
23	26	0	26	OK	0.72	
24	29	0	29	Change Filter	0.72	
25	32	0	32	Change Filter	0.91	
26	42	0	42	Change Filter	0.58	
27	26	0	26	OK	0.62	
28	26	0	26	OK	0.74	
29	26	0	26	OK	0.95	
30	27	0	27	OK	0.69	
31	35	0	35	Change Filter	0.71	

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <b>NO</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

**Notes:** Plant turbidity readings exceeded the limit of 1 NTU for the Upper Park three times during the month of May. Upon further investigating, it seems that the turbidimeter needs to be calibrated or replaced. The operator was refreshed on the Turbidity Rule & Tier II notice was delivered to customers. On May 5th CL<sub>2</sub> was below 0.2, during this time the plant was in a Boil Water Notice and we knew that there were issues. (BV)

**PRINTED NAME:** Brenda Vasquez

**SIGNATURE:** *Brenda L Vasquez* 6/9/2024

**PHONE #:** (541) 254-1909 **CERT#** T2D1-070226

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum. **This form Modified 3/6/2022**

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: B-Upper Park

<b>System Name:</b>	Whaleshead Beach Resort LLC	<b>ID#:</b> 41-94489	<b>Month/Year:</b>	May-24	<b>Disinfection Giardia Log Inactiv:</b>	<b>0.5</b>
---------------------	-----------------------------	----------------------	--------------------	--------	--	------------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
Daily @ 09:00	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	1.71	132	225.7	9.4	7.40	25.0	YES	25
2	1.92	132	253.4	11.8	7.40	21.9	YES	
3	1.92	132	253.4	12.8	7.40	20.3	YES	
4	0.62	132	81.8	12.5	7.30	17.2	YES	
5	0.16	132	21.1	10.0	7.20	18.8	YES	
6	0.63	132	83.2	13.9	6.90	13.5	YES	
7	0.69	132	91.1	12.8	7.00	15.2	YES	
8	1.12	132	147.8	12.7	7.00	16.1	YES	
9	1.05	132	138.6	13.1	7.10	16.1	YES	
10	0.85	132	112.2	16.7	6.90	11.5	YES	
11	0.49	132	64.7	13.4	6.80	13.3	YES	
12	1.21	132	159.7	12.1	7.00	17.2	YES	
13	0.62	132	81.8	16.7	6.80	10.8	YES	
14	1.50	132	198.0	12.1	7.20	19.1	YES	
15	1.02	132	134.6	15.0	6.70	12.2	YES	
16	0.79	132	104.3	12.7	7.20	16.7	YES	
17	0.86	132	113.5	13.0	7.20	16.5	YES	
18	0.41	132	54.1	12.5	7.10	15.6	YES	
19	0.40	132	52.8	11.1	6.80	15.7	YES	
20	0.34	132	44.9	11.4	7.00	16.4	YES	
21	1.56	132	205.9	11.2	7.50	22.6	YES	
22	1.89	132	249.5	12.8	7.00	17.5	YES	
23	1.03	132	136.0	13.1	7.40	18.0	YES	
24	0.40	132	52.8	10.7	7.40	19.8	YES	
25	0.38	132	50.2	13.0	7.10	15.1	YES	
26	0.21	132	27.7	12.2	7.20	16.4	YES	
27	0.61	132	80.5	11.8	7.30	18.2	YES	
28	1.18	132	155.8	11.9	7.20	18.6	YES	
29	1.31	132	172.9	14.0	6.80	14.0	YES	
30	0.63	132	83.2	12.5	7.10	16.0	YES	
31	0.67	132	88.4	13.6	7.00	14.4	YES	

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised 3/6/2022 PAX

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350