

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Curry

Cartridge or Bag Filtration

Month/Year: Sept. 2025

System Name:	Whaleshead Beach Resort LLC			ID#: 41	94489	WTP ID: TP-	B-Upper Park
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	32.00	1.00	31.00	Change Filter	0.29	0.29	
2	37.00	1.00	36.00	Change Filter	0.22	0.22	
3	22.00	1.00	21.00	OK	0.25	0.25	
4	24.00	1.00	23.00	OK	0.21	0.21	
5	32.00	1.00	31.00	Change Filter	0.18	0.18	
6	24.00	1.00	23.00	OK	0.24	0.24	
7	29.00	1.00	28.00	Change Filter	0.21	0.21	
8	32.00	1.00	31.00	Change Filter	0.20	0.20	
9	38.00	1.00	37.00	Change Filter	0.28	0.28	
10	43.00	1.00	42.00	Change Filter	0.25	0.25	
11	28.00	1.00	27.00	OK	0.27	0.27	
12	22.00	1.00	21.00	OK	0.24	0.24	
13	25.00	1.00	24.00	OK	0.20	0.20	
14	28.00	1.00	27.00	OK	0.27	0.27	
15	28.00	1.00	27.00	OK	0.21	0.21	
16	24.00	1.00	23.00	OK	0.16	0.16	
17	24.00	1.00	23.00	OK	0.26	0.26	
18	22.00	1.00	21.00	OK	0.26	0.26	
19	29.00	1.00	28.00	Change Filter	0.15	0.15	
20	24.00	1.00	23.00	OK	0.15	0.15	
21	28.00	1.00	27.00	OK	0.23	0.23	
22	29.00	1.00	28.00	Change Filter	0.16	0.16	
23	29.00	1.00	28.00	Change Filter	0.24	0.24	
24	30.00	1.00	29.00	Change Filter	0.21	0.21	
25	30.00	1.00	29.00	Change Filter	0.25	0.25	
26	31.00	1.00	30.00	Change Filter	0.24	0.24	
27	25.00	1.00	24.00	OK	0.27	0.27	
28	29.00	1.00	28.00	Change Filter	0.21	0.21	
29	15.00	1.00	14.00	OK	0.62	0.62	
30	16.00	1.00	15.00	OK	0.24	0.24	
31		1.00					

Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	Yes
Notes: PSI = pounds per square inch				PRINTED NAME: Giovanni Rangel	
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: <i>Giovanni Rangel</i>	
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				DATE: 10/09/2025	
				PHONE #: (541) 373-9150	
				CERT #: TTD1-859079	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: -Upper Par

System Name: Whaleshead Beach Resort LLC	ID#: 41	94489	Month/Year: Sept. 2025	Disinfection Giardia Log Inactiv:	1
--	---------	-------	------------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.58	132	76.6	13.8	6.91	27.2	YES	25
2	0.52	132	68.6	13.4	6.98	28.5	YES	25
3	0.5	132	66.0	15.1	6.87	24.3	YES	25
4	1.82	132	240.2	14.8	6.90	29.2	YES	25
5	0.63	132	83.2	13.8	6.83	26.6	YES	25
6	0.75	132	99.0	13.7	6.89	27.7	YES	25
7	0.69	132	91.1	13.9	6.87	27.0	YES	25
8	0.43	132	56.8	17.3	6.95	21.5	YES	25
9	0.82	132	108.2	16.4	6.96	23.9	YES	25
10	0.99	132	130.7	14.4	6.89	27.2	YES	25
11	1.58	132	208.6	14.1	6.93	30.1	YES	25
12	0.84	132	110.9	14.2	6.89	27.1	YES	25
13	0.86	132	113.5	14.0	6.86	27.2	YES	25
14	0.52	132	68.6	14.2	6.95	26.7	YES	25
15	0.5	132	66.0	14.3	6.94	26.4	YES	25
16	1.65	132	217.8	14.3	6.97	30.4	YES	25
17	0.99	132	130.7	14.3	6.83	26.8	YES	25
18	0.73	132	96.4	13.8	6.75	26.1	YES	25
19	0.56	132	73.9	14.1	6.77	25.3	YES	25
20	0.79	132	104.3	14.0	6.80	26.4	YES	25
21	0.75	132	99.0	13.6	6.83	27.3	YES	25
22	0.6	132	79.2	13.8	6.78	26.0	YES	25
23	1.44	132	190.1	14.8	6.93	28.3	YES	25
24	1.26	132	166.3	15.1	6.95	27.4	YES	25
25	0.92	132	121.4	14.0	6.82	27.0	YES	25
26	0.49	132	64.7	15.0	6.85	24.3	YES	25
27	0.47	132	62.0	14.4	6.95	26.2	YES	25
28	0.43	132	56.8	13.5	6.88	27.0	YES	25
29	0.41	132	54.1	14.5	6.90	25.4	YES	25
30	1.75	132	231.0	14.0	6.94	31.0	YES	25
31		132						25

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350