

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Curry

Cartridge or Bag Filtration

Month/Year: Oct-25

System Name:	Whaleshead Beach Resort LLC	ID#:	41	94489	WTP ID:	TP-	B-Upper Park
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1	19.00	1.00	18.00	OK	0.27	0.27	
2	20.00	1.00	19.00	OK	0.22	0.22	
3	20.00	1.00	19.00	OK	0.28	0.28	
4	21.00	1.00	20.00	OK	0.23	0.23	
5	22.00	1.00	21.00	OK	0.22	0.22	
6	22.00	1.00	21.00	OK	0.25	0.25	
7	22.00	1.00	21.00	OK	0.23	0.23	
8	22.00	1.00	21.00	OK	0.24	0.24	
9	22.00	1.00	21.00	OK	0.23	0.23	
10	26.00	1.00	25.00	OK	0.15	0.15	
11	24.00	1.00	23.00	OK	0.24	0.24	
12	20.00	1.00	19.00	OK	0.22	0.22	
13	20.00	1.00	19.00	OK	0.24	0.24	
14	26.00	1.00	25.00	OK	0.29	0.29	
15	26.00	1.00	25.00	OK	0.23	0.23	
16	27.00	1.00	26.00	OK	0.20	0.20	
17	27.00	1.00	26.00	OK	0.25	0.25	
18	27.00	1.00	26.00	OK	0.22	0.22	
19	27.00	1.00	26.00	OK	0.20	0.20	
20	23.00	1.00	22.00	OK	0.24	0.24	
21	27.00	1.00	26.00	OK	0.25	0.25	
22	27.00	1.00	26.00	OK	0.25	0.25	
23	26.00	1.00	25.00	OK	0.22	0.22	
24	27.00	1.00	26.00	OK	0.24	0.24	
25	28.00	1.00	27.00	OK	0.28	0.28	
26	28.00	1.00	27.00	OK	0.27	0.27	
27	28.00	1.00	27.00	OK	0.28	0.28	
28	29.00	1.00	28.00	Change Filter	0.25	0.25	
29	29.00	1.00	28.00	Change Filter	0.20	0.20	
30	29.00	1.00	28.00	Change Filter	0.20	0.20	
31	20.00	1.00	19.00	OK	0.25	0.25	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes	Yes	Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Giovanni Rangel	
	SIGNATURE: <i>Giovanni Rangel</i>	DATE: 11/6/2025
	PHONE #: (541) 373-9150	CERT #: 11D1-859079

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: -Upper Par

System Name: Whaleshead Beach Resort LLC	ID#: 41	94489	Month/Year: Oct-25	Disinfection Giardia Log Inactiv:	1
--	---------	-------	--------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	132	158.4	13.7	6.92	29.5	YES	25
2	0.9	132	118.8	13.0	6.91	29.8	YES	25
3	0.74	132	97.7	13.2	6.88	28.5	YES	25
4	0.52	132	68.6	14.4	6.95	26.3	YES	25
5	1.05	132	138.6	14.5	6.97	28.0	YES	25
6	0.66	132	87.1	14.9	6.95	25.9	YES	25
7	0.47	132	62.0	15.2	6.92	24.5	YES	25
8	0.44	132	58.1	13.6	6.85	26.5	YES	25
9	0.88	132	116.2	12.7	6.58	26.8	YES	25
10	1.17	132	154.4	12.7	6.55	27.4	YES	25
11	1.06	132	139.9	12.7	6.65	28.1	YES	25
12	0.89	132	117.5	12.7	6.86	29.8	YES	25
13	0.68	132	89.8	11.5	6.75	31.1	YES	25
14	1.26	132	166.3	12.7	6.80	30.4	YES	25
15	0.66	132	87.1	13.0	6.82	28.0	YES	25
16	0.62	132	81.8	12.3	6.75	29.4	YES	25
17	1.98	132	261.4	13.0	6.81	32.4	YES	25
18	1.24	132	163.7	13.1	6.77	29.2	YES	25
19	1.14	132	150.5	12.5	6.83	30.7	YES	25
20	0.78	132	103.0	12.6	6.85	29.5	YES	25
21	0.68	132	89.8	13.0	6.94	29.4	YES	25
22	0.61	132	80.5	13.3	6.91	28.2	YES	25
23	0.56	132	73.9	13.2	6.90	28.2	YES	25
24	0.54	132	71.3	13.8	6.91	27.1	YES	25
25	0.97	132	128.0	13.2	6.90	29.5	YES	25
26	0.91	132	120.1	11.9	6.88	32.5	YES	25
27	0.61	132	80.5	10.5	6.88	34.3	YES	25
28	0.71	132	93.7	12.0	6.90	31.8	YES	25
29	0.54	132	71.3	13.4	6.88	27.5	YES	25
30	0.62	132	81.8	13.3	7.00	29.2	YES	25
31	1.53	132	202.0	13.3	7.04	32.9	YES	25

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350