

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Curry

Cartridge or Bag Filtration

Month/Year: Dec-25

System Name: Whaleshead Beach Resort LLC ID#: 41 94489 WTP ID: TP- B-Upper Park

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	20.00	1.00	19.00	OK	0.18	0.18
2	18.00	1.00	17.00	OK	0.17	0.17
3	21.00	1.00	20.00	OK	0.16	0.16
4	21.00	1.00	20.00	OK	0.18	0.18
5	23.00	1.00	22.00	OK	0.18	0.18
6	26.00	1.00	25.00	OK	0.20	0.20
7	27.00	1.00	26.00	OK	0.18	0.18
8	11.00	1.00	10.00	OK	0.19	0.19
9	18.00	1.00	17.00	OK	0.16	0.16
10	19.00	1.00	18.00	OK	0.17	0.17
11	21.00	1.00	20.00	OK	0.17	0.17
12	27.00	1.00	26.00	OK	0.14	0.14
13	11.00	1.00	10.00	OK	0.13	0.13
14	11.00	1.00	10.00	OK	0.15	0.15
15	11.00	1.00	10.00	OK	0.19	0.19
16	18.00	1.00	17.00	OK	0.17	0.17
17	20.00	1.00	19.00	OK	0.20	0.20
18	21.00	1.00	20.00	OK	0.16	0.16
19	21.00	1.00	20.00	OK	0.17	0.17
20	23.00	1.00	22.00	OK	0.25	0.25
21	23.00	1.00	22.00	OK	0.22	0.22
22	24.00	1.00	23.00	OK	0.21	0.21
23	25.00	1.00	24.00	OK	0.25	0.25
24	25.00	1.00	24.00	OK	0.26	0.26
25	28.00	1.00	27.00	OK	0.29	0.29
26	28.00	1.00	27.00	OK	0.27	0.27
27	28.00	1.00	27.00	OK	0.28	0.28
28	28.00	1.00	27.00	OK	0.20	0.20
29	28.00	1.00	27.00	OK	0.20	0.20
30	28.00	1.00	27.00	OK	0.20	0.20
31	28.00	1.00	27.00	OK	0.16	0.16

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Giovanni Rangel
 SIGNATURE: *Giovanni Rangel* DATE: 01/01/2026
 PHONE #: (541) 373-9150 CERT #: TTD1-859079

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : -Upper Par

System Name: Whaleshead Beach Resort LLC	ID#: 41	94489	Month/Year: Dec-25	Disinfection Giardia Log Inactiv:	1
--	---------	-------	--------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.49	132	196.7	11.6	6.84	34.8	YES	25
2	0.53	132	70.0	11.1	6.81	32.0	YES	25
3	0.49	132	64.7	10.4	6.89	34.2	YES	25
4	0.78	132	103.0	11.3	6.92	33.7	YES	25
5	0.72	132	95.0	12.8	6.92	29.7	YES	25
6	0.6	132	79.2	12.5	6.95	30.2	YES	25
7	1.52	132	200.6	12.2	6.94	34.7	YES	25
8	1.6	132	211.2	13.4	7.06	33.2	YES	25
9	1.11	132	146.5	13.0	6.86	29.9	YES	25
10	0.56	132	73.9	13.5	6.95	28.1	YES	25
11	0.47	132	62.0	13.6	6.90	27.1	YES	25
12	1.07	132	141.2	13.7	6.93	29.2	YES	25
13	0.95	132	125.4	13.5	6.93	29.2	YES	25
14	0.78	132	103.0	11.6	7.02	34.2	YES	25
15	0.78	132	103.0	12.7	6.87	29.5	YES	25
16	0.45	132	59.4	14.4	6.97	26.3	YES	25
17	1.6	132	211.2	13.2	6.96	32.4	YES	25
18	1.4	132	184.8	11.5	7.00	36.6	YES	25
19	1	132	132.0	12.7	6.92	30.8	YES	25
20	0.58	132	76.6	9.6	6.92	36.8	YES	25
21	0.83	132	109.6	11.4	6.79	32.2	YES	25
22	0.44	132	58.1	12.1	6.88	30.5	YES	25
23	0.61	132	80.5	9.6	6.92	36.9	YES	25
24	0.68	132	89.8	10.0	7.00	37.2	YES	25
25	1.16	132	153.1	11.0	6.76	33.9	YES	25
26	1.98	132	261.4	11.1	6.74	36.6	YES	25
27	1.04	132	137.3	8.8	6.82	39.4	YES	25
28	0.77	132	101.6	9.7	6.87	36.7	YES	25
29	0.61	132	80.5	9.9	6.88	35.7	YES	25
30	0.64	132	84.5	11.1	6.96	34.1	YES	25
31	0.7	132	92.4	11.7	6.93	32.7	YES	25

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmcne@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350