

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Curry

Cartridge or Bag Filtration

Month/Year: Mar-26

System Name: Whaleshead Beach Resort LLC ID#: 41 94489 WTP ID: TP- B-Upper Park

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	30.00	1.00	29.00	Change Filter	0.20	0.20
2	30.00	1.00	29.00	Change Filter	0.26	0.26
3	30.00	1.00	29.00	Change Filter	0.22	0.22
4	30.00	1.00	29.00	Change Filter	0.24	0.24
5	30.00	1.00	29.00	Change Filter	0.25	0.25
6	30.00	1.00	29.00	Change Filter	0.26	0.26
7	27.00	1.00	26.00	OK	0.20	0.20
8	27.00	1.00	26.00	OK	0.22	0.22
9	30.00	1.00	29.00	Change Filter	0.21	0.21
10	30.00	1.00	29.00	Change Filter	0.19	0.19
11	28.00	1.00	27.00	OK	0.20	0.20
12	25.00	1.00	24.00	OK	0.20	0.20
13	28.00	1.00	27.00	OK	0.21	0.21
14	29.00	1.00	28.00	Change Filter	0.17	0.17
15	25.00	1.00	24.00	OK	0.19	0.19
16	27.00	1.00	26.00	OK	0.23	0.23
17	28.00	1.00	27.00	OK	0.20	0.20
18	28.00	1.00	27.00	OK	0.23	0.23
19	27.00	1.00	26.00	OK	0.22	0.22
20	28.00	1.00	27.00	OK	0.20	0.20
21	32.00	1.00	31.00	Change Filter	0.19	0.19
22	32.00	1.00	31.00	Change Filter	0.20	0.20
23	30.00	1.00	29.00	Change Filter	0.29	0.29
24	25.00	1.00	24.00	OK	0.25	0.25
25	25.00	1.00	24.00	OK	0.25	0.25
26	28.00	1.00	27.00	OK	0.18	0.18
27	29.00	1.00	28.00	Change Filter	0.23	0.23
28	29.00	1.00	28.00	Change Filter	0.17	0.17
29	29.00	1.00	28.00	Change Filter	0.19	0.19
30	26.00	1.00	25.00	OK	0.25	0.25
31	26.00	1.00	25.00	OK	0.16	0.16

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)
All daily turbidity readings ≤ 5 NTU?	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l?
		Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Giovanni Rangel

SIGNATURE: *Giovanni Rangel* DATE: 4/8/2026

PHONE #: (541) 373-9150 CERT #: T2D1-859079

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : Upper Par

System Name: Whaleshead Beach Resort LLC	ID#: 41	94489	Month/Year: Mar-26	Disinfection <i>Giardia</i> Log Inactiv: 0.5
--	---------	-------	--------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.76	37	65.1	13.1	6.80	15.7	YES	20
2	1.42	37	52.5	13.0	6.89	15.7	YES	20
3	1.13	37	41.8	13.1	6.86	14.9	YES	20
4	1	37	37.0	12.1	6.91	16.3	YES	20
5	1.09	37	40.3	11.3	6.87	17.1	YES	20
6	1.15	37	42.6	12.3	6.96	16.7	YES	20
7	1.05	37	38.9	12.6	6.89	15.4	YES	20
8	1.2	37	44.4	13.4	6.95	15.2	YES	20
9	1.21	37	44.8	11.6	6.95	17.5	YES	20
10	1.19	37	44.0	11.1	6.93	17.9	YES	20
11	1.05	37	38.9	10.9	6.98	18.2	YES	20
12	1.18	37	43.7	12.8	7.03	16.3	YES	20
13	1.14	37	42.2	12.4	7.00	16.8	YES	20
14	0.87	37	32.2	12.9	6.98	15.3	YES	20
15	1.62	37	59.9	12.2	6.82	16.9	YES	20
16	1.44	37	53.3	13.3	6.99	16.0	YES	20
17	1.12	37	41.4	12.4	6.83	15.8	YES	20
18	0.93	37	34.4	12.0	6.92	16.4	YES	20
19	0.81	37	30.0	12.3	6.89	15.7	YES	20
20	1.12	37	41.4	13.4	6.89	14.8	YES	20
21	1.18	37	43.7	13.7	6.95	14.9	YES	20
22	1.22	37	45.1	12.1	6.88	16.6	YES	20
23	0.77	37	28.5	11.9	6.97	16.5	YES	20
24	0.98	37	36.3	12.9	6.90	15.1	YES	20
25	1.47	37	54.4	11.1	6.89	18.2	YES	20
26	0.79	37	29.2	10.9	6.89	17.1	YES	20
27	0.8	37	29.6	12.2	6.87	15.7	YES	20
28	1.08	37	40.0	11.5	6.83	16.7	YES	20
29	1.2	37	44.4	12.1	6.73	15.7	YES	20
30	0.85	37	31.5	11.7	6.94	16.7	YES	20
31	1.45	37	53.7	12.3	6.80	16.3	YES	20

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350