

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Coos**
 Month/Year: **Mar-23**

System Name: **Coos Co Parks-LaVerne** ID#: **41 94557** WTP: **TP - B**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.04				
2			0.04				
3			0.03				
4			0.04				
5			0.03				
6			0.04				
7			0.03				
8			0.03				
9			0.03				
10			0.03				
11			0.03				
12			0.03				
13			0.03				
14			0.03				
15			0.03				
16			0.03				
17			0.04				
18			0.04				
19			0.03				
20			0.03				
21			0.04				
22			0.03				
23			0.03				
24			0.03				
25			0.03				
26			0.04				
27			0.04				
28			0.03				
29			0.03				
30			0.04				
31			0.03				

95% of daily turbidity readings ≤ 1 NTU? ²		All daily turbidity readings ≤ 5 NTU?		Monthly Summary (Answer Yes or No)	
<input checked="" type="radio"/> yes	<input type="radio"/> No	<input checked="" type="radio"/> yes	<input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
				<input checked="" type="radio"/> yes / <input type="radio"/> No	<input checked="" type="radio"/> yes / <input type="radio"/> No

Notes:

SIGNATURE: Calvin Napier **22-Mar**

PHONE #: (541)396-2344 **CERT #:**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : B

System Name: Coos Co. Parks Lav. ID#: 41 94557 Month/Year: Mar-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes /No	[GPM]
1	1	31.8	31.8	4.6	7.70	35.6	YES	1
2	1.2	31.8	38.2	5.1	7.70	35.2	YES	1
3	1.2	31.8	38.2	5.8	7.70	33.5	YES	1
4	1.2	31.8	38.2	5.3	7.60	33.5	YES	1
5	1.2	31.8	38.2	5.1	7.70	35.2	YES	1
6	1.2	31.8	38.2	4.8	7.80	37.3	YES	1
7	1.2	31.8	38.2	5.6	7.70	34.0	YES	1
8	1.2	31.8	38.2	5.7	7.70	33.8	YES	1
9	1.2	31.8	38.2	5.9	7.80	34.5	YES	1
10	1.2	31.8	38.2	6.4	7.90	34.6	YES	1
11	1.2	31.8	38.2	7.6	7.80	30.8	YES	1
12	1	31.8	31.8	8.4	7.70	27.5	YES	1
13	1.2	31.8	38.2	7.3	7.70	30.3	YES	1
14	1	31.8	31.8	7.9	7.80	29.5	YES	1
15	1.2	31.8	38.2	6.1	7.70	32.9	YES	1
16	1.2	31.8	38.2	6.1	7.90	35.3	YES	1
17	1.2	31.8	38.2	7.4	7.80	31.2	YES	1
18	1	31.8	31.8	8.2	7.70	27.8	YES	1
19	1.2	31.8	38.2	9.0	7.90	29.0	YES	1
20	1.2	31.8	38.2	7.7	7.80	30.6	YES	1
21	1	31.8	31.8	8.3	7.50	25.7	YES	1
22	1.2	31.8	38.2	7.6	7.30	25.7	YES	1
23	1.2	31.8	38.2	7.1	7.30	26.6	YES	1
24	1.2	31.8	38.2	6.9	7.00	24.2	YES	1
25	1.2	31.8	38.2	7.1	7.30	26.6	YES	1
26	1.2	31.8	38.2	6.8	7.60	30.2	YES	1
27	1.2	31.8	38.2	7.2	8.00	34.0	YES	1
28	1.2	31.8	38.2	6.5	8.00	35.7	YES	1
29	1.2	31.8	38.2	7.2	7.70	30.5	YES	1
30	1.2	31.8	38.2	6.9	7.60	30.0	YES	1
31	1.2	31.8	38.2	7.3	7.70	30.3	YES	1

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.