

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Coos**  
 Month/Year: **Jan-24**

System Name: **Coos Co Parks-LaVerne** ID#: **41** **94557** WTP : **TP - B**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			0.04				
2			0.04				
3			0.04				
4			0.03				
5			0.03				
6			0.03				
7			0.03				
8			0.03				
9			0.03				
10			0.04				
11			0.04				
12			0.03				
13			0.04				
14			0.04				
15			0.04				
16			0.03				
17			0.04				
18			0.03				
19			0.03				
20			0.03				
21			0.04				
22			0.03				
23			0.04				
24			0.04				
25			0.03				
26			0.04				
27			0.04				
28			0.03				
29			0.04				
30			0.04				
31			0.03				

		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<input checked="" type="radio"/> yes <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> yes <input type="radio"/> No	<input checked="" type="radio"/> yes <input type="radio"/> No	<input checked="" type="radio"/> yes <input type="radio"/> No
<b>Notes:</b>			
		<b>SIGNATURE:</b> Calvin Napier	<b>2-Jan</b>
		<b>PHONE #:</b> ( 541 )396-2344	<b>CERT #:</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : B

<b>System Name:</b> Coos Co. Parks Lav.	<b>ID#: 41</b>	<b>94557</b>	<b>Month/Year: Jan-24</b>	<b>Disinfection <i>Giardia</i> Log</b>	<b>Inactiv: 0.5</b>
---	----------------	--------------	---------------------------	--	---------------------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes /No	[GPM]
1	1.2	31.8	38.2	10.9	7.80	24.6	YES	1
2	1.2	31.8	38.2	11.6	7.60	21.9	YES	1
3	1.2	31.8	38.2	12.2	7.60	21.1	YES	1
4	1.2	31.8	38.2	12.7	7.60	20.3	YES	1
5	1.4	31.8	44.5	12.9	7.70	21.2	YES	1
6	1.4	31.8	44.5	12.1	7.70	22.5	YES	1
7	1.4	31.8	44.5	11.5	7.60	22.6	YES	1
8	1.4	31.8	44.5	11.2	7.80	24.7	YES	1
9	1.4	31.8	44.5	10.8	7.60	23.6	YES	1
10	1.4	31.8	44.5	10.3	7.70	25.3	YES	1
11	1.2	31.8	38.2	10.5	7.60	23.6	YES	1
12	1.2	31.8	38.2	9.7	7.70	25.8	YES	1
13	1.2	31.8	38.2	10.2	7.60	24.0	YES	1
14	1.2	31.8	38.2	10.8	7.80	24.8	YES	1
15	1.2	31.8	38.2	11.1	7.70	23.5	YES	1
16	1.2	31.8	38.2	11.4	7.60	22.2	YES	1
17	1	31.8	31.8	10.9	7.70	23.2	YES	1
18	1	31.8	31.8	10.3	7.70	24.2	YES	1
19	1	31.8	31.8	10.9	7.60	22.4	YES	1
20	1	31.8	31.8	11.3	7.70	22.6	YES	1
21	1	31.8	31.8	10.8	7.60	22.6	YES	1
22	1.2	31.8	38.2	10.6	7.80	25.1	YES	1
23	1.2	31.8	38.2	11.2	7.60	22.5	YES	1
24	1.2	31.8	38.2	11.7	7.70	22.5	YES	1
25	1.2	31.8	38.2	11.2	7.60	22.5	YES	1
26	1.2	31.8	38.2	10.8	7.70	23.9	YES	1
27	1.2	31.8	38.2	10.6	7.60	23.4	YES	1
28	1	31.8	31.8	11.1	7.70	22.9	YES	1
29	1	31.8	31.8	10.5	7.60	23.0	YES	1
30	1	31.8	31.8	10.9	7.70	23.2	YES	1
31	1	31.8	31.8	11.2	7.70	22.8	YES	1

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.