

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Coos**  
 Month/Year: **May-22**

System Name: **Coos Co Parks-LaVerne** ID#: **41 94557** WTP: **TP - B**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			0.03				
2			0.03				
3			0.03				
4			0.03				
5			0.04				
6			0.04				
7			0.03				
8			0.04				
9			0.03				
10			0.03				
11			0.04				
12			0.04				
13			0.04				
14			0.04				
15			0.03				
16			0.04				
17			0.03				
18			0.03				
19			0.03				
20			0.03				
21			0.03				
22			0.03				
23			0.03				
24			0.03				
25			0.04				
26			0.04				
27			0.03				
28			0.03				
29			0.03				
30			0.03				
31							

Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> yes / <input type="radio"/> No

**Notes:**

**SIGNATURE:** Calvin Napier **22-May**

**PHONE #:** ( 541 )396-2344 **CERT #:**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : B

System Name: Coos Co. Parks Lav. ID#: 41 94557 Month/Year: May-22 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes /No	[GPM]
1	1	31.8	31.8	10.4	6.70	17.0	YES	1
2	1	31.8	31.8	10.2	6.30	15.0	YES	1
3	1	31.8	31.8	9.8	5.80	13.0	YES	1
4	1	31.8	31.8	10.9	6.90	17.6	YES	1
5	1	31.8	31.8	11.6	6.80	16.3	YES	1
6	1	31.8	31.8	10.1	6.70	17.3	YES	1
7	1	31.8	31.8	10.8	6.90	17.7	YES	1
8	1	31.8	31.8	10.1	6.70	17.3	YES	1
9	1	31.8	31.8	9.5	7.10	20.6	YES	1
10	1	31.8	31.8	9.8	7.80	25.9	YES	1
11	1	31.8	31.8	11.2	7.50	21.2	YES	1
12	1	31.8	31.8	10.7	7.50	21.9	YES	1
13	1	31.8	31.8	9.1	7.50	24.4	YES	1
14	1	31.8	31.8	9.0	7.40	23.7	YES	1
15	1	31.8	31.8	8.9	6.90	20.0	YES	1
16	1	31.8	31.8	8.3	7.00	21.6	YES	1
17	1	31.8	31.8	8.8	6.90	20.2	YES	1
18	1	31.8	31.8	10.0	6.60	16.8	YES	1
19	1	31.8	31.8	9.2	6.60	17.7	YES	1
20	1	31.8	31.8	9.6	6.60	17.3	YES	1
21	1	31.8	31.8	10.0	6.30	15.2	YES	1
22	1	31.8	31.8	9.3	6.40	16.4	YES	1
23	1	31.8	31.8	9.9	6.30	15.3	YES	1
24	1	31.8	31.8	11.0	6.50	15.3	YES	1
25	1	31.8	31.8	10.7	6.40	15.0	YES	1
26	1.2	31.8	38.2	12.5	6.20	12.2	YES	1
27	1.3	31.8	41.3	11.4	6.40	14.9	YES	1
28	1.3	31.8	41.3	11.2	6.40	15.1	YES	1
29	1.3	31.8	41.3	12.6	6.40	13.2	YES	1
30	1.3	31.8	41.3	13.4	6.10	11.2	YES	1
31		31.8					NO	1

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.