

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Coos**
 Month/Year: **Oct-23**

System Name: Coos Co Parks-LaVerne		ID#: 41 94557		WTP : TP - B			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.03				
2			0.03				
3			0.03				
4			0.04				
5			0.04				
6			0.03				
7			0.03				
8			0.04				
9			0.04				
10			0.03				
11			0.03				
12			0.03				
13			0.03				
14			0.03				
15			0.04				
16			0.04				
17			0.04				
18			0.04				
19			0.03				
20			0.03				
21			0.04				
22			0.04				
23			0.04				
24			0.03				
25			0.03				
26			0.03				
27			0.04				
28			0.04				
29			0.03				
30			0.03				
31			0.04				

		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> yes <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> yes <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> yes <input type="radio"/> No		<input checked="" type="radio"/> yes <input type="radio"/> No
Notes:			
		SIGNATURE: Calvin Napier	22-Oct
		PHONE #: (541)396-2344	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : B

System Name: Coos Co. Parks Lav. ID#: 41 94557 Month/Year: Oct-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes /No	[GPM]
1	0.4	31.8	12.7	17.1	7.60	13.8	YES	1
2	0.6	31.8	19.1	16.9	7.70	14.9	YES	1
3	0.6	31.8	19.1	16.4	7.60	14.8	YES	1
4	0.6	31.8	19.1	16.2	7.60	15.0	YES	1
5	0.6	31.8	19.1	17.1	7.70	14.7	YES	1
6	0.8	31.8	25.4	17.5	7.60	14.1	YES	1
7	0.8	31.8	25.4	18.9	7.50	12.3	YES	1
8	0.8	31.8	25.4	19.5	7.50	11.9	YES	1
9	0.8	31.8	25.4	17.9	7.60	13.7	YES	1
10	0.6	31.8	19.1	17.5	7.70	14.3	YES	1
11	0.6	31.8	19.1	16.8	7.60	14.4	YES	1
12	0.6	31.8	19.1	15.9	7.50	14.8	YES	1
13	0.8	31.8	25.4	15.4	7.50	15.6	YES	1
14	0.8	31.8	25.4	15.9	7.60	15.7	YES	1
15	1	31.8	31.8	15.7	7.70	16.8	YES	1
16	1	31.8	31.8	16.3	7.50	15.0	YES	1
17	1	31.8	31.8	15.8	7.60	16.1	YES	1
18	1	31.8	31.8	16.0	7.60	15.9	YES	1
19	1	31.8	31.8	15.3	7.50	16.1	YES	1
20	1.2	31.8	38.2	17.1	7.50	14.6	YES	1
21	1.2	31.8	38.2	16.2	7.60	16.1	YES	1
22	1.2	31.8	38.2	17.0	7.60	15.2	YES	1
23	1.2	31.8	38.2	16.7	7.60	15.5	YES	1
24	1.2	31.8	38.2	15.2	7.80	18.5	YES	1
25	1	31.8	31.8	14.1	7.70	18.7	YES	1
26	1	31.8	31.8	12.9	7.60	19.6	YES	1
27	1	31.8	31.8	11.8	7.50	20.4	YES	1
28	1	31.8	31.8	10.2	7.60	23.5	YES	1
29	0.8	31.8	25.4	9.9	7.60	23.4	YES	1
30	0.8	31.8	25.4	9.3	7.70	25.3	YES	1
31	0.8	31.8	25.4	9.9	7.80	25.2	YES	1

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.