

**OHA - Drinking Water Services – Turbidity Monitoring Report Form County:  
Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems**

System Name: Lake Seaman / Kellers Landing ID #: 94645 WTP-: \_\_\_\_\_ Month/Year: Feb 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1				.946			
2				.975			
3				.931			
4				.842			
5				.912			
6				.745			
7				.852			
8				.941			
9				.945			
10				.823			
11				.856			
12				.978			
13				.821			
14				.745			
15				.721			
16				.732			
17				.942			
18				.861			
19				.821			
20				.893			
21				.941			
22				.782			
23				.876			
24				.942			
25				.734			
26				.698			
27				.935			
28				.892			
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME:	
	SIGNATURE:	DATE:
	PHONE #: (       )	CERT #: <u>2379</u>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services – Surface Water Quality Data Form**

System Name: Lake Selwyn / Kellers Landing ID #: 94645 WTP-: \_\_\_\_\_ Month/Year: Feb 2022

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 /	1.8	84	151	5.6	7.3	54	Yes	
2 /	1.8	84	151	5.6	7.3	54	Yes	
3 /	1.6	84	134	6.7	7.2	53	Yes	
4 /	1.6	84	134	6.7	7.3	53	Yes	
5 /	1.8	84	151	6.7	7.2	54	Yes	
6 /	1.7	84	142	6.7	7.2	54	Yes	
7 /	1.8	84	151	6.7	7.2	54	Yes	
8 /	1.8	84	151	7.2	7.2	54	Yes	
9 /	1.7	84	142	7.2	7.1	54	Yes	
10 /	1.6	84	134	7.2	7.1	53	Yes	
11 /	1.6	84	134	7.2	7.2	53	Yes	
12 /	1.7	84	142	6.7	7.2	54	Yes	
13 /	1.5	84	126	6.7	7.3	53	Yes	
14 /	1.6	84	134	6.7	7.3	53	Yes	
15 /	1.6	84	134	7.2	7.3	53	Yes	
16 /	1.6	84	134	7.2	7.3	53	Yes	
17 /	1.8	84	151	6.7	7.2	54	Yes	
18 /	1.8	84	151	6.7	7.3	54	Yes	
19 /	1.8	84	151	7.2	7.3	54	Yes	
20 /	1.7	84	142	7.2	7.2	54	Yes	
21 /	1.8	84	151	6.7	7.3	54	Yes	
22 /	1.7	84	142	6.7	7.3	54	Yes	
23 /	1.8	84	151	6.7	7.2	54	Yes	
24 /	1.6	84	134	6.7	7.3	53	Yes	
25 /	1.8	84	151	6.7	7.3	54	Yes	
26 /	1.6	84	134	7.2	7.2	53	Yes	
27 /	1.7	84	142	7.2	7.2	54	Yes	
28 /	1.7	84	142	7.2	7.2	54	Yes	
29 /								
30 /								
31 /								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised September 2016  
 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf)

Return by 10<sup>th</sup> of following month by email, fax, or mail to:  
[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350