

**OHA - Drinking Water Services – Turbidity Monitoring Report Form County:
Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems**

System Name: Kellers landing ID #: _____ WTP: 94645 Month/Year: May 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.045			
2				.045			
3				.045			
4				.037			
5				.038			
6				.042			
7				.148			
8				.156			
9				.162			
10				.280			
11				.048			
12				.043			
13				.073			
14				.050			
15				.078			
16				.050			
17				.101			
18				.102			
19				.056			
20				.069			
21				.078			
22				.056			
23				.050			
24				.078			
25				.051			
26				.045			
27				.053			
28				.053			
29				.115			
30				.028			
31				.031			

Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:	PRINTED NAME:	
	SIGNATURE:	DATE:
	PHONE #: ()	CERT #: <u>2379</u>

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: Lake Selmac Kelleys Landing ID #: 94645 WTP: _____ Month/Year: May 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 /	1.8	84	151	13.3	7.1	41	Yes	
2 /	1.8	84	151	13.3	7.1	41	Yes	
3 /	1.7	84	142	13.3	7.2	41	Yes	
4 /	1.4	84	117	13.3	7.1	39	Yes	
5 /	1.2	84	100	15.0	7.3	25	Yes	
6 /	1.4	84	117	15.0	7.3	26	Yes	
7 /	1.4	84	117	13.9	7.1	39	Yes	
8 /	1.4	84	117	13.9	7.2	39	Yes	
9 /	1.4	84	117	13.9	7.2	39	Yes	
10 /	1.5	84	126	13.9	7.2	40	Yes	
11 /	1.6	84	134	13.9	7.1	40	Yes	
12 /	1.8	84	151	13.9	7.2	41	Yes	
13 /	2.0	84	168	13.9	7.3	41	Yes	
14 /	1.9	84	159	13.9	7.1	41	Yes	
15 /	1.9	84	159	15.0	7.2	28	Yes	
16 /	1.9	84	159	16.1	7.3	29	Yes	
17 /	1.9	84	159	16.7	7.3	29	Yes	
18 /	1.5	84	126	16.7	7.3	26	Yes	
19 /	1.5	84	126	16.1	7.1	26	Yes	
20 /	1.6	84	134	16.7	7.1	26	Yes	
21 /	1.4	84	117	16.7	7.2	26	Yes	
22 /	1.4	84	117	16.7	7.3	26	Yes	
23 /	1.5	84	126	16.7	7.3	26	Yes	
24 /	1.5	84	126	17.8	7.1	26	Yes	
25 /	1.4	84	117	17.8	7.1	26	Yes	
26 /	1.4	84	117	19.4	7.1	26	Yes	
27 /	1.5	84	126	19.4	7.1	26	Yes	
28 /	1.5	84	126	19.4	7.1	26	Yes	
29 /	1.5	84	126	19.4	7.1	26	Yes	
30 /	1.7	84	142	19.4	7.2	27	Yes	
31 /	1.7	84	142	19.4	7.2	27	Yes	

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised September 2016
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350