

**OHA - Drinking Water Services – Turbidity Monitoring Report Form County:
Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems**

System Name: Lake Superior Kellers Landery ID #: 94645 WTP-: Month/Year: July 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.284			
2				.261			
3				.096			
4				.085			
5				.071			
6				.082			
7				.040			
8				.250			
9				.268			
10				.044			
11				.048			
12				.172			
13				.211			
14				.253			
15				.149			
16				.094			
17				.169			
18				.155			
19				.176			
20				.231			
21				.112			
22				.107			
23				.113			
24				.200			
25				.291			
26				.176			
27				.231			
28				.096			
29				.215			
30				.091			
31				.096			

Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME:	
	SIGNATURE:	DATE:
	PHONE #: ()	CERT #: <u>2379</u>

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: LAKE SEASIDE Kellers landing **ID #:** 94645 **WTP-:** **Month/Year:** July 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 /	1.7	84	142	23.3	7.3	20	Yes	
2 /	1.7	84	142	23.3	7.3	20	Yes	
3 /	2.0	84	168	23.3	7.2	21	Yes	
4 /	2.0	84	168	23.3	7.3	21	Yes	
5 /	1.7	84	142	23.9	7.1	20	Yes	
6 /	1.5	84	126	23.9	7.4	20	Yes	
7 /	1.5	84	126	23.9	7.3	20	Yes	
8 /	1.5	84	126	23.9	7.1	20	Yes	
9 /	1.5	84	126	25.0	7.2	20	Yes	
10 /	1.5	84	126	25.0	7.2	20	Yes	
11 /	1.4	84	117	25.0	7.2	19	Yes	
12 /	1.7	84	142	25.6	7.3	20	Yes	
13 /	1.7	84	142	25.0	7.3	20	Yes	
14 /	1.7	84	142	25.0	7.3	20	Yes	
15 /	1.1	84	92	25.5	7.3	19	Yes	
16 /	1.2	84	100	25.5	7.3	19	Yes	
17 /	1.1	84	92	25.5	7.3	19	Yes	
18 /	1.1	84	92	25.5	7.3	19	Yes	
19 /	1.2	84	100	25.5	7.2	19	Yes	
20 /	1.1	84	92	25.5	7.2	19	Yes	
21 /	1.2	84	100	25.5	7.2	19	Yes	
22 /	1.4	84	117	25.5	7.3	19	Yes	
23 /	1.4	84	117	25.5	7.4	19	Yes	
24 /	1.4	84	117	25.5	7.4	19	Yes	
25 /	1.3	84	109	25.5	7.2	19	Yes	
26 /	1.4	84	117	25.5	7.2	19	Yes	
27 /	1.4	84	117	25.5	7.2	19	Yes	
28 /	1.3	84	109	25.5	7.2	19	Yes	
29 /	1.3	84	109	25.5	7.3	19	Yes	
30 /	1.4	84	117	25.5	7.3	19	Yes	
31 /	1.1	84	92	25.5	7.3	19	Yes	

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised September 2016

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350