

OHA - Drinking Water Program - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Josephine  
 Month/Year: Apr-23  
 WTP: TP - HOORS GURCH CREEK

System Name: Rand ID#: 41 94758

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			0.03				0.03
2			0.03				0.03
3			0.04				0.04
4			0.04				0.04
5			0.04				0.04
6			0.04				0.04
7			0.04				0.04
8			0.04				0.04
9			0.04				0.04
10			0.04				0.04
11			0.04				0.04
12			0.04				0.04
13			0.04				0.04
14			0.03				0.03
15			0.03				0.03
16			0.04				0.04
17			0.04				0.04
18			0.03				0.03
19			0.03				0.03
20			0.04				0.04
21			0.04				0.04
22			0.04				0.04
23			0.04				0.04
24			0.04				0.04
25			0.03				0.03
26			0.04				0.04
27			0.04				0.04
28			0.04				..037
29			0.04				0.04
30			0.04				0.04
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

Notes:  
 WTP-A TP FOR HOORS GURCH CREEK  
 MEMBRANE FILTRATION

PRINTED NAME: Greg Montague  
 SIGNATURE: *[Signature]*  
 PHONE #: (541) 618-2480/541 659-8904  
 DATE: 5/2/2023  
 CERT #: D-09444

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

\* CURRENTLY 3 RESIDENTS ON SITE. NOT OPEN TO THE PUBLIC YET.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: *RMD*

System Name: *RMD WWT STA WFO* ID#: 41 94758 Month/Year: Apr-23 Disinfection *Giardia* Log Inactiv: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.51	62	31.6	11.9	7.33	18.1	Yes	3.63
2	0.6	62	37.2	11.8	7.35	18.5	Yes	3.42
3	0.64	62	39.7	11.9	7.34	18.4	Yes	3.47
4	0.8	62	49.6	11.9	7.33	18.7	Yes	3.55
5	0.88	62	54.6	11.9	7.37	19.1	Yes	3.69
6	0.89	62	55.2	10.4	7.40	21.3	Yes	3.37
7	0.91	62	56.4	10.0	8.38	31.2	Yes	3.71
8	0.9	62	55.8	10.2	8.43	31.3	Yes	3.55
9	0.87	62	53.9	10.4	8.23	28.6	Yes	3.29
10	0.84	62	52.1	10.7	7.84	24.3	Yes	3.77
11	0.82	62	50.8	10.5	7.12	19.1	Yes	3.48
12	0.88	62	54.6	12.8	6.42	12.5	Yes	3.66
13	0.85	62	52.7	11.8	7.26	18.5	Yes	3.83
14	0.83	62	51.5	10.9	7.40	20.5	Yes	3.42
15	0.82	62	50.8	10.4	7.22	19.9	Yes	3.57
16	0.84	62	52.1	10.6	7.61	22.6	Yes	3.61
17	0.83	62	51.5	10.3	7.29	20.5	Yes	3.49
18	0.89	62	55.2	10.8	7.14	19.0	Yes	3.64
19	0.87	62	53.9	10.4	7.38	21.1	Yes	3.52
20	0.87	62	53.9	10.1	7.64	23.7	Yes	3.28
21	0.86	62	53.3	10.2	7.75	24.4	Yes	3.68
22	0.85	62	52.7	10.0	7.63	23.6	Yes	3.72
23	0.84	62	52.1	10.1	7.79	24.8	Yes	3.74
24	0.86	62	53.3	10.4	7.81	24.6	Yes	3.64
25	0.84	62	52.1	10.5	7.67	23.2	Yes	3.81
26	0.88	62	54.6	10.7	7.90	25.0	Yes	3.85
27	0.87	62	53.9	10.1	7.52	22.7	Yes	3.97
28	0.88	62	54.6	10.2	7.28	20.7	Yes	3.58
29	0.86	62	53.3	10.1	7.06	19.2	Yes	3.83
30	0.84	62	52.1	10.2	7.27	20.5	Yes	3.63
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012