

AUG 2025


OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: Aug-25

System Name:		Rand Ranger Station & Info. Center			ID#: 41 94758	WTP ID: TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	29.00	26.00	3.00	25.00	0.03	0.03
2	29.00	26.00	3.00	25.00	0.04	0.04
3	29.00	27.00	2.00	25.00	0.04	0.04
4	29.00	26.00	3.00	25.00	0.03	0.03
5	29.00	27.00	2.00	25.00	0.03	0.03
6	29.00	26.00	3.00	25.00	0.03	0.03
7	29.00	26.00	3.00	25.00	0.05	0.05
8	29.00	26.00	3.00	25.00	0.19	0.19
9	29.00	26.00	3.00	25.00	0.03	0.03
10	29.00	26.00	3.00	25.00	0.03	0.03
11	29.00	26.00	3.00	25.00	0.03	0.03
12	29.00	26.00	3.00	25.00	0.04	0.04
13	29.00	26.00	3.00	25.00	0.03	0.03
14	29.00	26.00	3.00	25.00	0.03	0.03
15	29.00	26.00	3.00	25.00	0.03	0.03
16	29.00	26.00	3.00	25.00	0.03	0.03
17	29.00	26.00	3.00	25.00	0.02	0.02
18	29.00	26.00	3.00	25.00	0.02	0.02
19	29.00	26.00	3.00	25.00	0.02	0.02
20	29.00	26.00	3.00	25.00	0.03	0.03
21	29.00	26.00	3.00	25.00	0.03	0.03
22	29.00	27.00	2.00	25.00	0.02	0.02
23	29.00	26.00	3.00	25.00	0.18	0.18
24	29.00	26.00	3.00	25.00	0.03	0.03
25	29.00	26.00	3.00	25.00	0.04	0.04
26	29.00	26.00	3.00	25.00	0.02	0.02
27	29.00	26.00	3.00	25.00	0.03	0.03
28	29.00	26.00	3.00	25.00	0.03	0.03
29	29.00	26.00	3.00	25.00	0.17	0.17
30	29.00	26.00	3.00	25.00	0.04	0.04
31	29.00	26.00	3.00	25.00	0.04	0.04

Cartridge & Bag Filtration 95% of daily turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All daily turbidity readings ≤ 5 NTU? ☒ Yes / ☐ No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl2 residual at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID		PRINTED NAME: Greg Montague SIGNATURE:  PHONE #: (541) 659-6904 DATE: 9/05/2025 CERT #: D-09444	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

AUG 2025

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: ind Ranger Station & Info. Cen ID#: 41 94758

Month/Year:

Aug-25

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.12	62	69.4	25.1	8.95	29.0	YES	3
2	1.1	62	68.2	24.8	8.93	29.3	YES	3
3	1.06	62	65.7	24.3	8.90	29.8	YES	3
4	1.03	62	63.9	23.8	8.70	28.5	YES	3
5	0.98	62	60.8	23.6	8.78	29.6	YES	3
6	1.1	62	68.2	23.3	8.98	33.0	YES	3
7	1.2	62	74.4	23.4	8.98	33.1	YES	3
8	1.18	62	73.2	23.0	8.99	34.1	YES	3
9	1.15	62	71.3	23.5	8.98	32.7	YES	3
10	1.12	62	69.4	24.1	8.99	31.5	YES	3
11	1.08	62	67.0	24.6	8.96	30.0	YES	3
12	1.01	62	62.6	25.4	8.92	27.8	YES	3
13	1.23	62	76.3	26.4	8.90	26.4	YES	3
14	1.21	62	75.0	25.6	8.94	28.2	YES	3
15	1.18	62	73.2	25.0	8.85	28.3	YES	3
16	1.15	62	71.3	24.6	8.97	30.3	YES	3
17	1.12	62	69.4	24.4	9.01	31.1	YES	3
18	1.09	62	67.6	24.2	9.01	31.4	YES	3
19	1.08	62	67.0	24.1	8.98	31.2	YES	3
20	1.06	62	65.7	23.7	8.83	30.2	YES	3
21	1.03	62	63.9	23.3	8.61	28.5	YES	3
22	0.93	62	57.7	24.2	8.92	29.8	YES	3
23	1.09	62	67.6	24.9	8.82	27.9	YES	3
24	1.11	62	68.8	25.1	8.90	28.4	YES	3
25	1.09	62	67.6	25.3	8.92	28.2	YES	3
26	1.05	62	65.1	25.4	8.93	28.0	YES	3
27	1.03	62	63.9	25.7	8.88	26.9	YES	3
28	1	62	62.0	25.6	8.88	26.9	YES	3
29	1.03	62	63.9	25.6	8.82	26.4	YES	3
30	1.02	62	63.2	24.4	8.93	29.8	YES	3
31	1	62	62.0	24.1	8.91	30.1	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350