

SEP 2025

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: Sep-25

System Name: Rand Ranger Station & Info. Center			ID#: 41	94758	WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	29.00	27.00	2.00	25.00	0.29	0.29
2	29.00	26.00	3.00	25.00	0.03	0.03
3	29.00	26.00	3.00	25.00	0.18	0.18
4	29.00	26.00	3.00	25.00	0.04	0.04
5	29.00	26.00	3.00	25.00	0.70	0.70
6	28.00	26.00	2.00	25.00	0.04	0.04
7	29.00	26.00	3.00	25.00	0.03	0.03
8	29.00	26.00	3.00	25.00	0.03	0.03
9	29.00	26.00	3.00	25.00	0.03	0.03
10	29.00	26.00	3.00	25.00	0.04	0.04
11	29.00	26.00	3.00	25.00	0.05	0.05
12	29.00	26.00	3.00	25.00	0.04	0.04
13	29.00	26.00	3.00	25.00	0.03	0.03
14	29.00	26.00	3.00	25.00	0.03	0.03
15	29.00	26.00	3.00	25.00	0.03	0.03
16	29.00	26.00	3.00	25.00	0.03	0.03
17	29.00	26.00	3.00	25.00	0.03	0.03
18	29.00	26.00	3.00	25.00	0.03	0.03
19	29.00	26.00	3.00	25.00	0.02	0.02
20	29.00	26.00	3.00	25.00	0.04	0.04
21	29.00	26.00	3.00	25.00	0.03	0.03
22	29.00	26.00	3.00	25.00	0.04	0.04
23	29.00	26.00	3.00	25.00	0.04	0.04
24	29.00	26.00	3.00	25.00	0.07	0.07
25	29.00	26.00	3.00	25.00	0.17	0.17
26	29.00	26.00	3.00	25.00	0.04	0.04
27	29.00	26.00	3.00	25.00	0.04	0.04
28	29.00	26.00	3.00	25.00	0.04	0.04
29	29.00	26.00	3.00	25.00	0.03	0.03
30	29.00	26.00	3.00	25.00	0.03	0.03

Cartridge & Bag Filtration 95% of daily turbidity readings $\leq$ 1 NTU? Yes / No All daily turbidity readings $\leq$ 5 NTU? Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) Yes / No All Cl2 residual at entry point $\geq$ 0.2 mg/l? Yes / No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.		PRINTED NAME: Greg Montague SIGNATURE:  PHONE #: (541) 659-6904	
		DATE: 10/8/2025 CERT #: D-09444	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

SEP 2025

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

Disinfection
Giardia Log
Inactiv:

1

System Name: ind Ranger Station & Info. Cen ID#: 41 94758

Month/Year:

Sep-25

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.96	62	59.5	24.2	8.96	30.3	YES	3
2	0.92	62	57.0	24.4	9.01	30.4	YES	3
3	0.86	62	53.3	24.6	8.86	28.1	YES	3
4	0.87	62	53.9	24.0	8.88	29.6	YES	3
5	1.03	62	63.9	24.2	8.89	29.8	YES	3
6	1.06	62	65.7	24.1	8.87	29.9	YES	3
7	1.14	62	70.7	23.4	8.92	32.2	YES	3
8	1.22	62	75.6	22.8	8.95	34.2	YES	3
9	1.32	62	81.8	22.5	8.90	34.6	YES	3
10	1.24	62	76.9	22.1	8.93	35.6	YES	3
11	1.09	62	67.6	21.4	8.91	36.4	YES	3
12	1.02	62	63.2	21.4	8.99	37.2	YES	3
13	0.96	62	59.5	22.2	8.98	34.9	YES	3
14	0.91	62	56.4	21.6	8.98	36.1	YES	3
15	0.84	62	52.1	21.3	8.97	36.4	YES	3
16	0.79	62	49.0	20.6	8.97	38.0	YES	3
17	1.1	62	68.2	21.6	8.98	36.9	YES	3
18	1.03	62	63.9	22.1	8.93	34.8	YES	3
19	1.07	62	66.3	21.5	8.98	37.1	YES	3
20	1.05	62	65.1	22.2	8.97	35.2	YES	3
21	1.02	62	63.2	21.5	8.98	36.8	YES	3
22	0.98	62	60.8	20.7	8.97	38.5	YES	3
23	0.95	62	58.9	20.4	8.99	39.5	YES	3
24	0.92	62	57.0	20.7	8.97	38.3	YES	3
25	0.84	62	52.1	20.7	9.00	38.4	YES	3
26	0.83	62	51.5	20.4	8.98	38.8	YES	3
27	0.95	62	58.9	19.6	8.99	41.6	YES	3
28	1.17	62	72.5	20.2	8.98	40.9	YES	3
29	1.24	62	76.9	20.6	8.97	40.0	YES	3
30	1.16	62	71.9	21.4	9.01	38.1	YES	3

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised November 2022