

OHA - Drinking Water Services - Turbidity Monitoring Report Form
Cartridge or Bag Filtration

County: DOUGLAS

System Name: ON THE RIVER GOLF & RV RESORT ID #41: 94929 WTP-:

Month/Year: 9/20/25

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	62	60	2	20	.019	.019
2	62	60	2	20	.019	.019
3	62	60	2	20	.019	.019
4	62	60	2	20	.019	.019
5	62	60	2	20	.019	.019
6	62	60	2	20	.019	.019
7	62	60	2	20	.019	.019
8	62	60	2	20	.019	.019
9	62	60	2	20	.019	.019
10	62	60	2	20	.019	.019
11	62	60	2	20	.019	.019
12	62	60	2	20	.019	.019
13	62	60	2	20	.019	.019
14	62	60	2	20	.019	.019
15	62	60	2	20	.019	.019
16	62	60	2	20	.019	.019
17	62	60	2	20	.019	.019
18	62	60	2	20	.019	.019
19	62	60	2	20	.019	.019
20	62	60	2	20	.019	.019
21	62	60	2	20	.019	.019
22	62	60	2	20	.019	.019
23	62	60	2	20	.019	.019
24	62	60	2	20	.019	.019
25	62	60	2	20	.019	.019
26	62	60	2	20	.019	.019
27	62	60	2	20	.019	.019
28	62	60	2	20	.019	.019
29	62	60	2	20	.019	.019
30	62	60	2	20	.019	.019
31						

Cartridge Filtration 95% of daily turbidity readings ≤ 1 NTU? <u>Yes</u> / No All daily turbidity readings ≤ 5 NTU? <u>Yes</u> / No Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <u>Yes</u> / No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No	
PRINTED NAME: <u>STEVE SUMNER</u> SIGNATURE: <u>[Signature]</u> DATE: <u>10/7/2025</u>		PHONE #: <u>(541) 167-3505</u> CERT #: <u>N/A</u>	

RECEIVED

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OCT 14 2025

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ON THE RIVER GOLF + RV ID #41: 94929 WTP: _____ Month/Year: 9/2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/19A	.6	58	34.8	22	7.5	21	YES	30
2/19A	.6	58	34.8	22	7.5	21	YES	30
3/19A	.6	58	34.8	22	7.5	21	YES	30
4/19A	.6	58	34.8	22	7.5	21	YES	30
5/19A	.6	58	34.8	22	7.5	21	YES	30
6/19A	.6	58	34.8	22	7.5	21	YES	30
7/19A	.6	58	34.8	22	7.5	21	YES	30
8/19A	.6	58	34.8	22	7.5	21	YES	30
9/19A	.6	58	34.8	22	7.5	21	YES	30
10/19A	.6	58	34.8	22	7.5	21	YES	30
11/19A	.6	58	34.8	22	7.5	21	YES	30
12/19A	.6	58	34.8	22	7.5	21	YES	30
13/19A	.6	58	34.8	21	7.5	21	YES	30
14/19A	.6	58	34.8	22	7.5	21	YES	30
15/19A	.6	58	34.8	21	7.5	21	YES	30
16/19A	.6	58	34.8	21	7.5	21	YES	30
17/19A	.6	58	34.8	21	7.5	21	YES	30
18/19A	.6	58	34.8	21	7.5	21	YES	30
19/19A	.6	58	34.8	21	7.5	21	YES	30
20/19A	.6	58	34.8	21	7.5	21	YES	30
21/19A	.6	58	34.8	21	7.5	21	YES	30
22/19A	.6	58	34.8	20	7.5	21	YES	30
23/19A	.6	58	34.8	21	7.5	21	YES	30
24/19A	.6	58	34.8	21	7.5	21	YES	30
25/19A	.6	58	34.8	21	7.5	21	YES	30
26/19A	.6	58	34.8	21	7.5	21	YES	30
27/19A	.6	58	34.8	20	7.5	21	YES	30
28/19A	.6	58	34.8	20	7.5	21	YES	30
29/19A	.6	58	34.8	20	7.5	21	YES	30
30/19A	.6	58	34.8	20	7.5	21	YES	30
31/								

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Revised October 2013

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

RECEIVED

OCT 14 2025