

OHA - Drinking Water Services - Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: DOUGLAS


System Name: ON THE RIVER GOLF & RV RESORT ID #41: 94929 WTP-: _____ Month/Year: 12/2025

| DAY | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the Day ¹ [NTU] |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|---|
| 1 | 62 | 60 | 2 | 20 | .019 | .019 |
| 2 | 62 | 60 | 2 | 20 | .019 | .019 |
| 3 | 62 | 60 | 2 | 20 | .019 | .019 |
| 4 | 62 | 60 | 2 | 20 | .019 | .019 |
| 5 | 62 | 60 | 2 | 20 | .019 | .019 |
| 6 | 62 | 60 | 2 | 20 | .019 | .019 |
| 7 | 62 | 60 | 2 | 20 | .019 | .019 |
| 8 | 62 | 60 | 2 | 20 | .019 | .019 |
| 9 | 62 | 60 | 2 | 20 | .019 | .019 |
| 10 | 62 | 60 | 2 | 20 | .019 | .019 |
| 11 | 62 | 60 | 2 | 20 | .019 | .019 |
| 12 | 62 | 60 | 2 | 20 | .019 | .019 |
| 13 | 62 | 60 | 2 | 20 | .019 | .019 |
| 14 | 62 | 60 | 2 | 20 | .019 | .019 |
| 15 | 62 | 60 | 2 | 20 | .019 | .019 |
| 16 | 62 | 60 | 2 | 20 | .019 | .019 |
| 17 | 62 | 60 | 2 | 20 | .019 | .019 |
| 18 | 62 | 60 | 2 | 20 | .019 | .019 |
| 19 | 62 | 60 | 2 | 20 | .019 | .019 |
| 20 | 62 | 60 | 2 | 20 | .019 | .019 |
| 21 | 62 | 60 | 2 | 20 | .019 | .019 |
| 22 | 62 | 60 | 2 | 20 | .019 | .019 |
| 23 | 62 | 60 | 2 | 20 | .019 | .019 |
| 24 | 62 | 60 | 2 | 20 | .019 | .019 |
| 25 | 62 | 60 | 2 | 20 | .019 | .019 |
| 26 | 62 | 60 | 2 | 20 | .019 | .019 |
| 27 | 62 | 60 | 2 | 20 | .019 | .019 |
| 28 | 62 | 60 | 2 | 20 | .019 | .019 |
| 29 | 62 | 60 | 2 | 20 | .019 | .019 |
| 30 | 62 | 60 | 2 | 20 | .019 | .019 |
| 31 | 62 | 60 | 2 | 20 | .019 | .019 |

JAN 08 2026

RECEIVED

Certification Drinking Water Services

| | | | |
|---|--|---|-----------------------|
| Cartridge Filtration 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No | | Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No | |
| Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. | | PRINTED NAME: <u>STEVE SUMNER</u> | |
| | | SIGNATURE:  | DATE: <u>1/4/2026</u> |
| | | PHONE #: <u>(541) 679-3505</u> | CERT #: <u>N/A</u> |

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ON THE RIVER GOLF, RV ID #41: 94929 WTP-: Month/Year: 12/2025

| Date / Time | Minimum Cl ₂ Residual at 1 st User (C) ² | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|------|-----|-------------|----------------------|-------------------------|
| | [ppm or mg/L] | [minutes] | C X T | [°C] | | Use tables | Yes / No | [GPM] |
| 11 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 21 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 31 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 41 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 51 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 61 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 71 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 81 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 91 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 10 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 11 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 12 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 13 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 14 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 15 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 16 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 17 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 18 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 19 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 20 9A | .6 | 58 | 34.8 | 18 | 7.5 | 21 | YES | 30 |
| 21 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 22 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 23 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 24 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 25 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 26 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 27 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 28 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 29 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 30 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |
| 31 9A | .6 | 58 | 34.8 | 17 | 7.5 | 29 | YES | 30 |

Certification Drinking Water Services

JAN 08 2026

RECEIVED

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised October 2013
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf