

OHA - Drinking Water Services – Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: DOUGLAS

System Name: ON THE RIVER GOLF & RV RESORT ID #41: 94929 WTP.: _____ Month/Year: 3/2026

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	58	54	4	20	.039	.039
2	58	54	4	20	.039	.039
3	58	54	4	20	.039	.039
4	58	54	4	20	.039	.039
5	58	54	4	20	.039	.039
6	58	54	4	20	.039	.039
7	58	54	4	20	.039	.039
8	58	54	4	20	.039	.039
9	58	54	4	20	.039	.039
10	58	54	4	20	.039	.039
11	58	54	4	20	.039	.039
12	58	54	4	20	.039	.039
13	58	54	4	20	.039	.039
14	58	54	4	20	.039	.039
15	58	54	4	20	.039	.039
16	58	54	4	20	.039	.039
17	58	54	4	20	.039	.039
18	58	54	4	20	.039	.039
19	58	54	4	20	.039	.039
20	58	54	4	20	.039	.039
21	58	54	4	20	.039	.039
22	58	54	4	20	.039	.039
23	58	54	4	20	.039	.039
24	58	54	4	20	.039	.039
25	58	54	4	20	.039	.039
26	58	54	4	20	.039	.039
27	58	54	4	20	.039	.039
28	58	54	4	20	.039	.039
29	58	54	4	20	.039	.039
30	58	54	4	20	.039	.039
31	58	54	4	20	.039	.039

Certification Drinking Water Services

APR 13 2026

RECEIVED

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<u>Yes</u> / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / <u>No</u>	<u>Yes</u> / No	Yes / <u>No</u>
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>STEVE SUMNER</u>	
		SIGNATURE: <u>[Signature]</u>	DATE: <u>4/7/2026</u>
		PHONE #: <u>541 1679-3505</u>	CERT #: <u>N/A</u>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ON THE RIVER GOLF + RV ID #41: 94929 WTP-: Month/Year: 3/2026

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/9A	.6	58	34.8	17	7.5	29	YES	30
2/9A	.6	58	34.8	17	7.5	29	YES	30
3/9A	.6	58	34.8	17	7.5	29	YES	30
4/9A	.6	58	34.8	17	7.5	29	YES	30
5/9A	.6	58	34.8	17	7.5	29	YES	30
6/9A	.6	58	34.8	17	7.5	29	YES	30
7/9A	.6	58	34.8	17	7.5	29	YES	30
8/9A	.6	58	34.8	18	7.5	21	YES	30
9/9A	.6	58	34.8	18	7.5	21	YES	30
10/9A	.6	58	34.8	18	7.5	21	YES	30
11/9A	.6	58	34.8	18	7.5	21	YES	30
12/9A	.6	58	34.8	17	7.5	29	YES	30
13/9A	.6	58	34.8	17	7.5	29	YES	30
14/9A	.6	58	34.8	18	7.5	21	YES	30
15/9A	.6	58	34.8	18	7.5	21	YES	30
16/9A	.6	58	34.8	18	7.5	21	YES	30
17/9A	.6	58	34.8	18	7.5	21	YES	30
18/9A	.6	58	34.8	18	7.5	21	YES	30
19/9A	.6	58	34.8	18	7.5	21	YES	30
20/9A	.6	58	34.8	18	7.5	21	YES	30
21/9A	.6	58	34.8	18	7.5	21	YES	30
22/9A	.6	58	34.8	18	7.5	21	YES	30
23/9A	.6	58	34.8	18	7.5	21	YES	30
24/9A	.6	58	34.8	18	7.5	21	YES	30
25/9A	.6	58	34.8	18	7.5	21	YES	30
26/9A	.6	58	34.8	18	7.5	21	YES	30
27/9A	.6	58	34.8	18	7.5	21	YES	30
28/9A	.6	58	34.8	18	7.5	21	YES	30
29/9A	.6	58	34.8	18	7.5	21	YES	30
30/9A	.6	58	34.8	18	7.5	21	YES	30
31/9A	.6	58	34.8	18	7.5	21	YES	30

APR 13 2026

RECEIVED

Certification Drinking Water Services

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised October 2013
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf