

OHA - Drinking Water Services – Turbidity Monitoring Report Form  
Cartridge or Bag Filtration

County: DOUGLAS

System Name: ON THE RIVER GOLF & RV RESORT ID #41: 94929 WTP-: Month/Year: 2/2021

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	62	62	∅	20	.019	.019
2	62	62	∅	20	.019	.019
3	62	62	∅	20	.019	.019
4	62	62	∅	20	.019	.019
5	62	62	∅	20	.019	.019
6	62	62	∅	20	.019	.019
7	62	62	∅	20	.019	.019
8	62	62	∅	20	.019	.019
9	62	62	∅	20	.019	.019
10	62	62	∅	20	.019	.019
11	62	62	∅	20	.019	.019
12	62	62	∅	20	.019	.019
13	62	62	∅	20	.019	.019
14	62	62	∅	20	.019	.019
15	62	62	∅	20	.019	.019
16	62	62	∅	20	.019	.019
17	62	62	∅	20	.019	.019
18	62	62	∅	20	.019	.019
19	62	62	∅	20	.019	.019
20	62	62	∅	20	.019	.019
21	62	62	∅	20	.019	.019
22	62	62	∅	20	.019	.019
23	62	62	∅	20	.019	.019
24	62	62	∅	20	.019	.019
25	62	62	∅	20	.019	.019
26	62	62	∅	20	.019	.019
27	62	62	∅	20	.019	.019
28	62	62	∅	20	.019	.019
29						
30						
31						

<b>Cartridge Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes:</b> PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <b>STEVE SUMNER</b> SIGNATURE: <i>[Signature]</i> DATE: <b>2/8/2021</b> PHONE #: <b>(541) 679-3505</b> CERT #: <b>N/A</b>	

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.



OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ON THE RIVER GOLF + RV ID #41: 94929 WTP-: Month/Year: 2/2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
11 9A	.6	58	34.8	17	7.5	29	YES	30
21 9A	.6	58	34.8	17	7.5	29	YES	30
31 9A	.6	58	34.8	17	7.5	29	YES	30
41 9A	.6	58	34.8	17	7.5	29	YES	30
51 9A	.6	58	34.8	17	7.5	29	YES	30
61 9A	.6	58	34.8	17	7.5	29	YES	30
71 9A	.6	58	34.8	17	7.5	29	YES	30
81 9A	.6	58	34.8	17	7.5	29	YES	30
91 9A	.6	58	34.8	17	7.5	29	YES	30
10 19A	.6	58	34.8	17	7.5	29	YES	30
11 19A	.6	58	34.8	17	7.5	29	YES	30
12 19A	.6	58	34.8	17	7.5	29	YES	30
13 19A	.6	58	34.8	17	7.5	29	YES	30
14 19A	.6	58	34.8	17	7.5	29	YES	30
15 19A	.6	58	34.8	17	7.5	29	YES	30
16 19A	.6	58	34.8	17	7.5	29	YES	30
17 19A	.6	58	34.8	17	7.5	29	YES	30
18 19A	.6	58	34.8	17	7.5	29	YES	30
19 19A	.6	58	34.8	17	7.5	29	YES	30
20 19A	.6	58	34.8	17	7.5	29	YES	30
21 19A	.4	58	34.8	17	7.5	29	YES	30
22 19A	.6	58	34.8	17	7.5	29	YES	30
23 19A	.6	58	34.8	17	7.5	29	YES	30
24 19A	.6	58	34.8	17	7.5	29	YES	30
25 19A	.6	58	34.8	17	7.5	29	YES	30
26 19A	.6	58	34.8	17	7.5	29	YES	30
27 19A	.6	58	34.8	17	7.5	29	YES	30
28 19A	.6	58	34.8	17	7.5	29	YES	30
29 /								
30 /								
31 /								

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours.

Revised October 2013

Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartndge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartndge.pdf)

