

OHA - Drinking Water Services – Turbidity Monitoring Report Form
 Cartridge or Bag Filtration

County: DOUGLAS

System Name: ON THE RIVER GOLF + RV RESORT ID #41: 94929 WTP-: _____ Month/Year: 12/2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	62	60	2	20	.019	.019
2	62	60	2	20	.019	.019
3	62	60	2	20	.019	.019
4	62	60	2	20	.019	.019
5	62	60	2	20	.019	.019
6	62	60	2	20	.019	.019
7	62	60	2	20	.019	.019
8	62	60	2	20	.019	.019
9	62	60	2	20	.019	.019
10	62	60	2	20	.019	.019
11	62	60	2	20	.019	.019
12	62	60	2	20	.019	.019
13	62	60	2	20	.019	.019
14	62	60	2	20	.019	.019
15	62	60	2	20	.019	.019
16	62	60	2	20	.019	.019
17	62	60	2	20	.019	.019
18	62	60	2	20	.019	.019
19	62	60	2	20	.019	.019
20	62	60	2	20	.019	.019
21	62	60	2	20	.019	.019
22	62	60	2	20	.019	.019
23	62	60	2	20	.019	.019
24	62	60	2	20	.019	.019
25	62	60	2	20	.019	.019
26	62	60	2	20	.019	.019
27	62	60	2	20	.019	.019
28	62	60	2	20	.019	.019
29	62	60	2	20	.019	.019
30	62	60	2	20	.019	.019
31	62	60	2	20	.019	.019

JAN 09 2023

RECEIVED

JAN 09 2023

RECEIVED

Drinking Water Services Certification

Drinking Water Services Certification

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <u>Yes/No</u> All daily turbidity readings ≤ 5 NTU? <u>Yes/No</u>		CT's met everyday? (see back) <u>Yes/No</u>	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes/No</u>
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>STEVE SUMNER</u>	
		SIGNATURE: <u>[Signature]</u>	DATE: <u>1/7/2023</u>
		PHONE #: <u>(541) 1679-3505</u>	CERT #: <u>N/A</u>

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: ON THE RIVER GOLF - RV ID #41: 94929 WTP-: Month/Year: 12/2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/1/2023	.6	58	34.8	17	7.5	29	YES	30
2/1/2023	.6	58	34.8	17	7.5	29	YES	30
3/1/2023	.6	58	34.8	17	7.5	29	YES	30
4/1/2023	.6	58	34.8	17	7.5	29	YES	30
5/1/2023	.6	58	34.8	17	7.5	29	YES	30
6/1/2023	.6	58	34.8	17	7.5	29	YES	30
7/1/2023	.6	58	34.8	17	7.5	29	YES	30
8/1/2023	.6	58	34.8	17	7.5	29	YES	30
9/1/2023	.6	58	34.8	17	7.5	29	YES	30
10/1/2023	.6	58	34.8	17	7.5	29	YES	30
11/1/2023	.6	58	34.8	17	7.5	29	YES	30
12/1/2023	.6	58	34.8	17	7.5	29	YES	30
13/1/2023	.6	58	34.8	17	7.5	29	YES	30
14/1/2023	.6	58	34.8	17	7.5	29	YES	30
15/1/2023	.6	58	34.8	17	7.5	29	YES	30
16/1/2023	.6	58	34.8	17	7.5	29	YES	30
17/1/2023	.6	58	34.8	17	7.5	29	YES	30
18/1/2023	.6	58	34.8	17	7.5	29	YES	30
19/1/2023	.6	58	34.8	17	7.5	29	YES	30
20/1/2023	.6	58	34.8	17	7.5	29	YES	30
21/1/2023	.6	58	34.8	17	7.5	29	YES	30
22/1/2023	.6	58	34.8	17	7.5	29	YES	30
23/1/2023	.6	58	34.8	17	7.5	29	YES	30
24/1/2023	.6	58	34.8	17	7.5	29	YES	30
25/1/2023	.6	58	34.8	17	7.5	29	YES	30
26/1/2023	.6	58	34.8	17	7.5	29	YES	30
27/1/2023	.6	58	34.8	17	7.5	29	YES	30
28/1/2023	.6	58	34.8	17	7.5	29	YES	30
29/1/2023	.6	58	34.8	17	7.5	29	YES	30
30/1/2023	.6	58	34.8	17	7.5	29	YES	30
31/1/2023	.6	58	34.8	17	7.5	29	YES	30

Certification
Drinking Water Services

RECEIVED
JAN 09 2023

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised October 2013
Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf