

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: DEER CREEK CENTER ID #: OR4185360 WTP: WTP-A Month/Year: Feb 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1				0.016			
2				0.026			
3				0.026			
4				0.026			
5				0.026			
6				0.026			
7				0.026			
8				0.026			
9				0.026			
10				0.026			
11				0.026			
12				0.026			
13				0.026			
14				0.026			
15				0.026			
16				0.026			
17				0.026			
18				0.026			
19				0.026			
20				0.026			
21				0.026			
22				0.026			
23				0.026			
24				0.026			
25				0.026			
26				0.026			
27				0.026			
28				0.026			
29				0.026			
30				0.026			
31				0.026			

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes/No	CTs met everyday? (600 back) Yes/No	All Cl ₂ residual priority point ≥ 0.2 mg/l? Yes/No
All daily turbidity readings ≤ 5 NTU?	Yes/No		
Notes:		PRINTED NAME: Lillie Hazelton	DATE: 3-3-21
		SIGNATURE: [Signature]	CERT #:
		PHONE #: 541 415-9788	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

Lillie 541 787-5303
 Deer Creek
 ATT Robert
 971 673-0416

PAGE 1 of 2 FAX 971 673-0694

OHA - Drinking Water Program - Surface Water Quality Data Form

DEER CREEK CENTER ID #: OR4195360 WTP: WTP-A Month/Year: Feb. 202

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp.	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/	1.0	2.0	2.0	10.0	8.2	4	.023	
2/	1.0	2.0	2.0	10.0	8.2	4	.023	
3/	1.0	2.0	2.0	10.0	8.2	4	.023	
4/	1.0	2.0	2.0	10.0	8.2	4	.023	
5/	1.0	2.0	2.0	10.0	8.2	4	.023	
6/	1.0	2.0	2.0	10.0	8.2	4	.023	
7/	1.0	2.0	2.0	10.0	8.2	4	.023	
8/	1.0	2.0	2.0	10.0	8.2	4	.023	
9/	1.0	2.0	2.0	10.0	8.2	4	.023	
10/	1.0	2.0	2.0	10.0	8.2	4	.023	
11/	1.0	2.0	2.0	10.0	8.2	4	.023	
12/	1.0	2.0	2.0	10.0	8.2	4	.023	
13/	1.0	2.0	2.0	10.0	8.2	4	.023	
14/	1.0	2.0	2.0	10.0	8.2	4	.023	
15/	1.0	2.0	2.0	10.0	8.2	4	.023	
16/	1.0	2.0	2.0	10.0	8.2	4	.023	
17/	1.0	2.0	2.0	10.0	8.2	4	.023	
18/	1.0	2.0	2.0	10.0	8.2	4	.023	
19/	1.0	2.0	2.0	10.0	8.2	4	.023	
20/	1.0	2.0	2.0	10.0	8.2	4	.023	
21/	1.0	2.0	2.0	10.0	8.2	4	.023	
22/	1.0	2.0	2.0	10.0	8.2	4	.023	
23/	1.0	2.0	2.0	10.0	8.2	4	.023	
24/	1.0	2.0	2.0	10.0	8.2	4	.023	
25/	1.0	2.0	2.0	10.0	8.2	4	.023	
26/	1.0	2.0	2.0	10.0	8.2	4	.023	
27/	1.0	2.0	2.0	10.0	8.2	4	.023	
28/	1.0	2.0	2.0	10.0	8.2	4	.023	
29/	1.0	2.0	2.0	10.0	8.2	4	.023	
30/	1.0	2.0	2.0	10.0	8.2	4	.023	
31/								

²If Cl₂ at entry point = 0.2 mg/L OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/urb-all-unfiltered.cdf