

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: DEER CREEK CENTER ID #: OR4195360 WTP: WTP-A Month/Year: March 2021

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day (NTU)
1				0.29			
2				0.50			
3				0.30			
4				0.20			
5				1.030			
6				0.34			
7				0.34			
8				0.34			
9				0.34			
10				0.31			
11				0.31			
12				0.30			
13				0.33			
14				0.32			
15				0.33			
16				0.33			
17				0.32			
18				0.32			
19				0.33			
20				0.33			
21				0.33			
22				0.33			
23				0.33			
24				0.33			
25				0.33			
26				0.33			
27				0.33			
28				0.33			
29				0.36			
30				0.36			
31				0.36			

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	Notes: <u>New System up and on line for data April 1, 2021</u>		
PRINTED NAME: <u>Lillie Hazelton</u>		DATE: <u>4/1/2021</u>	
SIGNATURE: <u>Lillie Hazelton</u>		PHONE #: <u>1541 415-9788</u>	
PHONE #: <u>1541 415-9788</u>		CERT #:	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. Filtered systems only.

Lillie 541 787-5200  
 Deer Creek  
 ATT Robert  
 971 673-0416

OHA - Drinking Water Program - Surface Water Quality Data Form

DEER CREEK CENTER ID #: OR4195360 WTP: WTP-A Month/Year: March 2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1' User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/	1.0	2.0	2.0	10.0	8.2	.23	Y	
2/	1.0	2.0	2.0	10.0	8.2	.23	Y	
3/	1.0	2.0	2.0	10.0	8.2	.23	Y	
4/	1.0	2.0	2.0	10.0	8.2	.23	Y	
5/	1.0	2.0	2.0	10.0	8.2	.23	Y	
6/	1.0	2.0	2.0	10.0	8.2	.23	Y	
7/	1.0	2.0	2.0	10.0	8.2	.23	Y	
8/	1.0	2.0	2.0	10.0	8.2	.23	Y	
9/	1.0	2.0	2.0	10.0	8.2	.23	Y	
10/	1.0	2.0	2.0	10.0	8.2	.23	Y	
11/	1.0	2.0	2.0	10.0	8.2	.23	Y	
12/	1.0	2.0	2.0	10.0	8.2	.23	Y	
13/	1.0	2.0	2.0	10.0	8.2	.23	Y	
14/	1.0	2.0	2.0	10.0	8.2	.23	Y	
15/	1.0	2.0	2.0	10.0	8.2	.23	Y	
16/	1.0	2.0	2.0	10.0	8.2	.23	Y	
17/	1.0	2.0	2.0	10.0	8.2	.23	Y	
18/	1.0	2.0	2.0	10.0	8.2	.23	Y	
19/	1.0	2.0	2.0	10.0	8.2	.23	Y	
20/	1.0	2.0	2.0	10.0	8.2	.23	Y	
21/	1.0	2.0	2.0	10.0	8.2	.23	Y	
22/	1.0	2.0	2.0	10.0	8.2	.23	Y	
23/	1.0	2.0	2.0	10.0	8.2	.23	Y	
24/	1.0	2.0	2.0	10.0	8.2	.23	Y	
25/	1.0	2.0	2.0	10.0	8.2	.23	Y	
26/	1.0	2.0	2.0	10.0	8.2	.23	Y	
27/	1.0	2.0	2.0	10.0	8.2	.23	Y	
28/	1.0	2.0	2.0	10.0	8.2	.23	Y	
29/	1.0	2.0	2.0	10.0	8.2	.23	Y	
30/	1.0	2.0	2.0	10.0	8.2	.23	Y	
31/	1.0	2.0	2.0	10.0	8.2	.23	Y	

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.  
 Download form at: [www.public.health.creos.ca/Health/Environment/DrinkingWater/Monitoring/Documents/df-unfiltered.pdf](http://www.public.health.creos.ca/Health/Environment/DrinkingWater/Monitoring/Documents/df-unfiltered.pdf)