

Deer Creek/SFI #41 95360 Feb 1 2023

OHA - Drinking Water Services - Surface Water Quality Data Form

 County: **Josephine**

Cartridge or Bag Filtration

 Month/Year: **Feb 2023**

System Name:	Deer Creek/SFI			ID#:	41- 95360	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the day (NTU)	
1	40.00	40.00	0.00	40.00	0.33	0.03	
2	40.00	40.00	0.00	40.00	0.33	0.03	
3	40.00	40.00	0.00	40.00	0.34	0.03	
4	40.00	40.00	0.00	40.00	0.34	0.03	
5	40.00	40.00	0.00	40.00	0.36	0.03	
6	40.00	40.00	0.00	40.00	0.36	0.03	
7	40.00	40.00	0.00	40.00	0.36	0.03	
8	40.00	40.00	0.00	40.00	0.36	0.03	
9	40.00	40.00	0.00	40.00	0.36	0.03	
10	40.00	40.00	0.00	40.00	0.34	0.03	
11	40.00	40.00	0.00	40.00	0.34	0.03	
12	40.00	40.00	0.00	40.00	0.34	0.03	
13	40.00	40.00	0.00	40.00	0.34	0.03	
14	40.00	40.00	0.00	40.00	0.34	0.03	
15	40.00	40.00	0.00	40.00	0.34	0.03	
16	40.00	40.00	0.00	40.00	0.35	0.02	
17	40.00	40.00	0.00	40.00	0.35	0.02	
18	40.00	40.00	0.00	40.00	0.35	0.02	
19	40.00	40.00	0.00	40.00	0.35	0.02	
20	40.00	40.00	0.00	40.00	0.35	0.02	
21	40.00	40.00	0.00	40.00	0.34	0.02	
22	40.00	40.00	0.00	40.00	0.34	0.02	
23	40.00	40.00	0.00	40.00	0.34	0.02	
24	40.00	40.00	0.00	40.00	0.34	0.03	
25	40.00	40.00	0.00	40.00	0.34	0.03	
26	40.00	40.00	0.00	40.00	0.03	0.03	
27	40.00	40.00	0.00	40.00	0.03	0.03	
28	40.00	40.00	0.00	40.00	0.03	0.03	
					Monthly Summary (Answer Yes or No)		
					Yes	Yes	All Cl2 residual at entry point ≥ 0.2 mg/l†
					Yes	Yes	Yes
PSID = pounds per square inch difference (before filter - after filter)					Lillic Hazardon		
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					ish	2/1/2023	
† Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.					541 415-0780	CERT #:	

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: -

System Name:	Deer Creek/SFI	ID#: 41	95360	Month/Year:	Jan-23	Disinfection Gland/Log Inactive:	0.5
--------------	----------------	---------	-------	-------------	--------	----------------------------------	-----

Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		seconds	Yes / No	[GPM]
1	1	65	65.0	13.0	8.20	24.2	YES	6
2	1	80	80.0	13.0	8.20	24.2	YES	3
3	1	60	60.0	13.0	8.20	24.2	YES	4
4	1	85	85.0	13.0	8.20	24.2	YES	3.5
5	1	60	60.0	13.0	8.20	24.2	YES	6.4
6	1	70	70.0	13.0	8.20	24.2	YES	3.1
7	1	75	75.0	13.0	8.20	24.2	YES	2.9
8	1	70	70.0	13.0	8.20	24.2	YES	2.8
9	1	95	95.0	13.0	8.20	24.2	YES	3.7
10	1	75	75.0	13.0	8.20	24.2	YES	3.3
11	1	60	60.0	13.0	8.20	24.2	YES	4.3
12	1	70	70.0	13.0	8.20	24.2	YES	4.1
13	1	85	85.0	12.0	8.20	25.8	YES	6.4
14	1	60	60.0	13.0	8.20	24.2	YES	3.2
15	1	95	95.0	13.0	8.20	24.2	YES	6.4
16	1	70	70.0	13.0	8.20	24.2	YES	2.8
17	1	65	65.0	13.0	8.20	24.2	YES	2.7
18	1	80	80.0	13.0	8.20	24.2	YES	3.1
19	1	70	70.0	13.0	8.20	24.2	YES	6.3
20	1	85	85.0	13.0	8.20	24.2	YES	5.2
21	1	90	90.0	12.0	8.20	25.8	YES	3.7
22	1	85	85.0	12.0	8.20	25.8	YES	6.1
23	1	80	80.0	12.0	8.20	25.8	YES	5.2
24	1	65	65.0	12.0	8.20	25.8	YES	3.1
25	1	70	70.0	12.0	8.20	25.8	YES	3.7
26	1	70	70.0	12.0	8.20	25.8	YES	5.2
27	1	90	90.0	12.0	8.20	25.8	YES	4.7
28	1	80	80.0	12.0	8.20	25.8	YES	6.1
								6.3

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dws.dms@state.or.us: 671-673-9694; or Drinking Water Services, PG Box 14250, Portland, OR 97283-0250

PAGE 2 of 2

3/1/2023 14:21:53