

3					County:	Josephine	
Cartridge or Bag Filtration					Month/Year:	Jun-24	
System Name:	SISKIYOU FIELD INSTITUTE			ID#: 41	95360	WTP ID: TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]	
1	38.00		38.00		0.07	cloudy	
2	38.00		38.00		0.08	overcast	
3	38.00		38.00		0.07	rain	
4	38.00		38.00		0.04	sunny	
5	38.00		38.00		0.05	sunny	
6	38.00		38.00		0.06	sunny	
7	38.00		38.00		0.05	sunny	
8	38.00		38.00		0.04	overcast	
9	38.00		38.00		0.16	sunny	
10	38.00		38.00		0.05	sunny	
11	38.00		38.00		0.05	sunny	
12	38.00		38.00		0.06	sunny	
13	38.00		38.00		0.05	sunny	
14	38.00		38.00		0.03	overcast	
15	38.00		38.00		0.04	overcast	
16	38.00		38.00		0.06	overcast	
17	38.00		38.00		0.07	cloudy	
18	38.00		38.00		0.05	sunny	
19	38.00		38.00		0.05	sunny	
20	38.00		38.00		0.03	overcast	
21	38.00		38.00		0.04	sunny	
22	38.00		38.00		0.04	sunny	
23	38.00		38.00		0.05	sunny	
24	38.00		38.00		0.05	sunny	
25	38.00		38.00		0.03	sunny	
26	38.00		38.00		0.05	overcast	
27	38.00		38.00		0.06	sunny	
28	38.00		38.00		0.04	sunny	
29	38.00		38.00		0.03	overcast	
30	38.00		38.00		0.04	overcast	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?				Yes / No	Yes / No	Yes / No	
Notes: PSI = pounds per square inch					PRINTED NAME: LILLIE HAZELTON		
PSID = pounds per square inch difference (before filter - after filter)					SIGNATURE: LEH		June 2024
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					PHONE #: (541) 415-9788		CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form						WTP- :	A
System Name:	SISKIYOU FIELD INSTITUTE	ID#: 41	95360	Month/Year:		Disinfection <i>Giardia</i> Log Inactiv:	1

Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.5	71.94	36.0	19.0	8.30	31.9	YES	3.6
2	0.5	71.34	35.7	20.5	8.39	29.8	YES	3.63
3	0.5	71.94	36.0	19.3	8.48	33.4	YES	3.6
4	0.5	71.94	36.0	20.5	8.54	31.5	YES	3.6
5	0.5	71.15	35.6	22.5	8.55	27.7	YES	3.64
6	0.5	70.18	35.1	23.7	8.42	24.4	YES	3.69
7	0.5	70.18	35.1	28.9	8.08	15.1	YES	3.69
8	0.5	71.94	36.0	28.5	8.22	16.3	YES	3.6
9	0.5	72.54	36.3	25.4	8.47	22.1	YES	3.57
10	0.5	70.18	35.1	27.8	8.24	17.3	YES	3.69
11	0.5	72.95	36.5	24.5	8.43	23.2	YES	3.55
12	0.5	70.95	35.5	25.9	8.35	20.5	YES	3.65
13	0.5	72.54	36.3	22.2	8.70	29.9	YES	3.57
14	0.5	70.18	35.1	20.4	8.74	34.2	YES	3.69
15	0.5	71.94	36.0	20.2	8.70	34.1	YES	3.6
16	0.5	72.3	36.2	17.6	8.80	31.9	yes	3.61
17	0.5	72.75	36.3	17.6	8.85	29.9	yes	3.56
18	0.5	70.95	35.5	19.1	8.66	36.2	yes	3.65
19	0.5	70.95	35.5	19.1	8.70	36.7	yes	3.65
20	0.5	71.34	35.7	20.9	8.93	35.5	YES	3.63
21	0.5	69.06	34.5	24.8	8.58	24.0	YES	3.75
22	0.5	71.94	36.0	24.4	8.66	25.4	YES	3.6
23	0.5	71.15	35.6	26.7	8.55	20.9	YES	3.64
24	0.5	71.34	35.7	24.9	8.58	23.9	YES	3.63
25	0.5	70.18	35.1	25.4	8.61	23.3	YES	3.69
26	0.5	70.18	35.1	24.8	8.66	24.7	YES	3.69
27	0.5	71.34	35.7	23.7	8.77	27.7	YES	3.63
28	0.5	72.34	36.2	21.8	8.78	31.6	YES	3.58
29	0.5	69.81	34.9	24.4	8.62	25.0	YES	3.71
30	0.5	71.34	35.7	23.8	8.80	27.9	YES	3.63

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350