

OHA - Drinking Water Services - Surface Water Quality Data Form						County:	Josephine
Cartridge or Bag Filtration						Month/Year:	Nov 2024
System Name:	Siskiyou Field Institute			ID#: 41	95360	WTP ID: TP-	Takelma Creek
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]	
1	38.00		38.00	15.00	0.04		
2	38.00		38.00		0.05		
3	38.00		38.00		0.05		
4	38.00		38.00		0.05		
5	38.00		38.00		0.05		
6	38.00		38.00		0.04		
7	38.00		38.00		0.04		
8	38.00		38.00		0.03		
9	38.00		38.00		0.04		
10	38.00		38.00		0.04		
11	38.00		38.00		0.04		
12	38.00		38.00		0.04		
13	38.00		38.00		0.04		
14	38.00		38.00		0.04		
15	38.00		38.00		0.04		
16	38.00		38.00		0.04		
17	38.00		38.00		0.04		
18	38.00		38.00		0.05		
19	38.00		38.00		0.05		
20	38.00		38.00		0.05		
21	38.00		38.00		0.04		
22	38.00		38.00		0.04		
23	38.00		38.00		0.04		
24	38.00		38.00		0.04		
25	38.00		38.00		0.04		
26	38.00		38.00		0.04		
27	38.00		38.00		0.04		
28	38.00		38.00		0.04		
29	38.00		38.00		0.04		
30	38.00		38.00		0.04		
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?				yes	yes	yes	
Notes: PSI = pounds per square inch					Lillie Hazelton		
PSID = pounds per square inch difference (before filter - after filter)					LEH		
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					541 415-9788		CERT #:
<small>1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.</small>							
PAGE 1 of 2							
OHA - Drinking Water Services - Surface Water Quality Data Form						WTP - :	Takelma
System Name:	Siskiyou Field Institute	ID#: 41	95360	Month/Year:	Nov 2024	Disinfection <i>Giardia</i> Log Inactiv:	0.5

Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow	
#	Column 1	# [ppm or mg/L]	# [minutes]	# C X T	# [° C]	# Column 2	# formula	Yes / No	# [GPM]
1		0.6	69.25	41.6	11.2	9.10	36.0	YES	3.74
2		0.6	68.15	40.9	11.5	9.00	34.0	YES	3.8
3		0.6	66	39.6	11.0	9.30	39.3	YES	3.9
4		0.62	70.18	43.5	9.5	9.04	39.7	YES	3.69
5		0.6	70.38	42.2	9.3	8.70	35.4	YES	3.68
6		0.65	70	45.5	10.0	9.10	39.3	YES	3.7
7		0.6	70.58	42.3	9.0	9.00	40.4	YES	3.67
8		0.6	69.81	41.9	9.1	9.01	40.3	YES	3.71
9		0.6	69.43	41.7	12.0	9.06	33.6	YES	3.73
10		0.6	69.25	41.6	12.0	9.00	32.9	YES	3.74
11		0.55	69.81	38.4	13.0	9.05	31.4	YES	3.71
12		0.6	70.18	42.1	10.0	8.70	33.8	YES	3.69
13		0.6	70	42.0	10.0	8.70	33.8	YES	3.7
14		0.5	69.62	34.8	10.0	8.75	34.0	YES	3.72
15		0.55	70.18	38.6	9.6	8.99	38.4	YES	3.69
16		0.6	69.25	41.6	9.2	9.00	39.8	YES	3.74
17		0.6	70.18	42.1	6.0	8.50	41.3	YES	3.69
18		0.6	69.81	41.9	7.0	8.30	35.8	YES	371
19		0.55	70.38	38.7	7.0	8.50	38.3	YES	3.68
20		0.6	70	42.0	5.0	8.30	41.1	YES	3.7
21		0.6	69.25	41.6	6.1	8.30	38.1	YES	3.74
22		0.6	70.38	42.2	5.8	8.20	37.5	YES	3.68
23		0.5	71.94	36.0	7.0	8.00	31.8	YES	3.6
24		0.5	70.95	35.5	7.0	8.10	32.9	YES	3.65
25		0.5	71.94	36.0	7.2	8.00	31.3	YES	3.6
26		0.55	69.25	38.1	5.6	8.10	36.5	YES	3.74
27		0.55	70	35.0	5.4	8.10	32.9	YES	3.7
28		0.5	70.57	37.9	5.6	8.00	31.3	YES	3.67
29		0.55	70.38	38.7	5.0	7.00	25.5	YES	3.68
30		0.5	70.57	35.3	5.0	7.50	30.4	YES	3.67

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 2

Revised November 2022

