

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: Mar 2025

System Name:		Siskiyou Field Institute		ID#:	41	95360	WTP ID:	TP-	Takelma Creek
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]			
1	38.00		38.00	15.00	0.03				
2	38.00		38.00		0.03				
3	38.00		38.00		0.04				
4	38.00		38.00		0.04				
5	38.00		38.00		0.04				
6	38.00		38.00		0.04				
7	38.00		38.00		0.04				
8	38.00		38.00		0.04				
9	38.00		38.00		0.04				
10	38.00		38.00		0.04				
11	38.00		38.00		0.04				
12	38.00		38.00		0.04				
13	38.00		38.00		0.04				
14	38.00		38.00		0.04				
15	38.00		38.00		0.04				
16	38.00		38.00		0.04				
17	38.00		38.00		0.04				
18	38.00		38.00		0.04				
19	38.00		38.00		0.04				
20	38.00		38.00		0.04				
21	38.00		38.00		0.04				
22	38.00		38.00		0.04				
23	38.00		38.00		0.04				
24	38.00		38.00		0.04				
25	38.00		38.00		0.04				
26	38.00		38.00		0.04				
27	38.00		38.00		0.04				
28	38.00		38.00		0.04				
29	38.00		38.00		0.04				
30	38.00		38.00		0.04				
31	38.00		38.00		0.04				
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 1 NTU?					yes		CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?					yes		yes		
Notes: PSI = pounds per square inch					Lillie Hazelton				
PSID = pounds per square inch difference (before filter - after filter)					LEH				
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					541 415-9788				
					CERT #:				

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - :

Takelma

System Name:	Siskiyou Field Institute	ID#: 41	95360	Month/Year:	Mar 2025	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------------	---------	-------	-------------	----------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.55	69.25	38.1	10.5	8.89	34.8	YES	3.8
2	0.55	70	38.5	10.0	8.80	34.8	YES	3.7
3	0.55	69.62	38.3	9.0	8.85	38.0	YES	3.72
4	0.55	69.62	38.3	9.0	8.80	37.3	YES	3.72
5	0.55	70	38.5	9.0	8.85	38.0	YES	3.7
6	0.55	70	38.5	9.0	8.84	37.9	YES	3.7
7	0.55	68.15	37.5	10.0	8.80	34.8	YES	3.8
8	0.55	70	38.5	12.0	8.70	29.3	YES	3.7
9	0.55	71.94	39.6	9.0	8.80	37.3	YES	3.6
10	0.55	71.94	39.6	9.0	8.80	37.3	YES	3.6
11	0.55	68.15	37.5	7.0	8.00	31.9	YES	3.8
12	0.55	71.94	39.6	6.1	8.40	39.3	YES	3.6
13	0.55	71.94	39.6	6.1	8.40	39.3	YES	3.6
14	0.55	71.94	39.6	6.1	8.40	39.3	YES	3.6
15	0.55	74	40.7	6.0	8.45	40.3	YES	3.5
16	0.55	74	40.7	6.0	8.45	40.3	YES	3.5
17	0.55	74	40.7	6.0	8.45	40.3	YES	3.5
18	0.55	71.94	39.6	6.5	8.45	39.0	YES	3.6
19	0.55	74	40.7	6.0	8.45	40.3	YES	3.5
20	0.55	74	40.7	6.0	8.45	40.3	YES	3.5
21	0.55	74	40.7	6.0	8.45	40.3	YES	3.5
22	0.55	74	40.7	6.0	8.45	40.3	YES	3.6
23	0.55	74	40.7	6.0	8.45	40.3	YES	3.6
24	0.56	67.47	37.8	12.8	8.87	29.9	YES	3.84
25	0.56	67.47	37.8	14.5	8.87	26.7	YES	3.84
26	0.56	67.47	37.8	14.5	8.87	26.7	YES	3.84
27	0.56	70	35.0	9.0	8.80	29.3	YES	3.7
28	0.56	70	35.0	7.0	8.45	29.3	YES	3.7
29	0.56	70	39.2	7.0	8.45	37.7	YES	3.7
30	0.56	68.15	38.2	7.0	8.40	37.0	YES	3.8
31	0.56	68.15	38.2	7.0	8.40	37.0	YES	3.8

2 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DW

Revised November 2022