

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Josephine

Cartridge or Bag Filtration

Month/Year: Aug 2025

System Name: Siskiyou Field Institute ID#: 41 95360 WTP ID: TP- Takelma Creek

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	38.00		38.00	15.00	0.06	
2	38.00		38.00		0.06	
3	38.00		38.00		0.04	
4	38.00		38.00		0.06	
5	38.00		38.00		0.04	
6	38.00		38.00		0.04	
7	38.00		38.00		0.04	
8	38.00		38.00		0.04	
9	38.00		38.00		0.04	
10	38.00		38.00		0.04	
11	38.00		38.00		0.04	
12	38.00		38.00		0.04	
13	38.00		38.00		0.05	
14	38.00		38.00		0.05	
15	38.00		38.00		0.05	
16	38.00		38.00		0.04	
17	38.00		38.00		0.04	
18	38.00		38.00		0.04	
19	38.00		38.00		0.04	
20	38.00		38.00		0.04	
21	38.00		38.00		0.04	
22	38.00		38.00		0.04	
23	38.00		38.00		0.04	
24	38.00		38.00		0.04	
25	38.00		38.00		0.04	
26	38.00		38.00		0.04	
27	38.00		38.00		0.04	
28	38.00		38.00		0.04	
29	38.00		38.00		0.04	
30	38.00		38.00		0.04	
31	38.00		38.00		0.04	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	yes	yes	yes
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		Lillie Hazelton	
		LEH	
		541 415-9788	
		CERT #:	

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : Takelma

System Name:	Siskiyou Field Institute	ID#: 41	95360	Month/Year:	Aug 2025	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------------	---------	-------	-------------	----------	---	-----

Date / Time	Minimum Cl2 Residual at 1st User (C) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.55	67.62	37.2	23.2	9.00	15.7	YES	3.83
2	0.55	67.44	37.1	24.6	8.90	13.8	YES	3.84
3	0.55	67.27	37.0	24.5	8.80	13.4	YES	3.85
4	0.55	66.92	36.8	24.9	8.80	13.0	YES	3.87
5	0.55	67.62	37.2	23.9	8.90	14.4	YES	3.83
6	0.55	67.27	37.0	24.0	8.90	14.4	YES	3.85
7	0.55	68.15	37.5	24.5	8.80	13.4	YES	3.80
8	0.55	66.07	36.3	25.0	9.00	13.9	YES	3.92
9	0.55	68.15	37.5	24.0	8.70	13.3	YES	3.8
10	0.55	68.15	37.5	25.0	8.80	12.9	YES	3.8
11	0.55	66.41	36.5	25.0	8.80	12.9	YES	3.9
12	0.55	66.41	36.5	24.0	8.70	13.3	YES	3.9
13	0.55	64.75	35.6	28.0	9.00	11.4	YES	4
14	0.55	64.75	35.6	29.1	9.00	10.6	YES	4
15	0.55	65.73	36.2	28.0	8.80	10.6	YES	3.94
16	0.55	65.73	36.2	27.4	8.80	11.0	YES	3.94
17	0.55	65.73	36.2	26.2	9.00	12.9	YES	3.94
18	0.55	65.43	36.0	26.1	9.00	12.9	YES	3.94
19	0.55	66.41	36.5	26.0	8.90	12.6	YES	3.9
20	0.55	66.07	36.3	24.4	9.00	14.5	YES	3.92
21	0.55	64.75	40.7	31.2	8.90	8.8	YES	4
22	0.55	65.07	35.8	30.0	8.90	9.6	YES	3.98
23	0.55	64.75	35.6	30.0	8.90	9.6	YES	4
24	0.56	65.07	36.4	28.0	8.90	11.0	YES	3.98
25	0.56	66.41	37.2	27.0	8.80	11.3	YES	3.9
26	0.56	65.23	37.8	26.9	9.00	26.7	y	3.97
27	0.56	66.41	35.0	28.0	8.90	29.3	y	3.9
28	0.56	65.56	35.0	28.5	9.00	29.3	y	3.95
29	0.56	66.41	37.2	27.0	8.90	11.8	YES	3.9
30	0.56	66.41	37.2	27.0	8.90	11.8	YES	3.9
31	0.56	65.56	36.7	27.0	8.90	11.8	YES	3.95

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DV