

0.04

**Cartridge or Bag Filtration**

County: Josephine

Month/Year: Dec2025

**System Name:** Siskiyou Field Institute **ID#:** 41 **95360** **WTP ID:** TP- **Takelma Creek**

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day 1 [NTU]
1	38.00		38.00	15.00	0.04	
2	38.00		38.00		0.04	
3	38.00		38.00		0.04	
4	38.00		38.00		0.04	
5	38.00		38.00		0.04	
6	38.00		38.00		0.04	
7	38.00		38.00		0.04	
8	38.00		38.00		0.04	
9	38.00		38.00		0.04	
10	38.00		38.00		0.03	
11	38.00		38.00		0.03	
12	38.00		38.00		0.03	
13	38.00		38.00		0.03	
14	38.00		38.00		0.03	
15	38.00		38.00		0.03	
16	38.00		38.00		0.03	
17	38.00		38.00		0.03	
18	38.00		38.00		0.03	
19	38.00		38.00		0.03	
20	38.00		38.00		0.03	
21	38.00		38.00		0.03	
22	38.00		38.00		0.03	
23	38.00		38.00		0.03	
24	38.00		38.00		0.03	
25	38.00		38.00		0.03	
26	38.00		38.00		0.03	
27	38.00		38.00		0.03	
28	38.00		38.00		0.03	
29	38.00		38.00		0.03	
30	38.00		38.00		0.03	
31	38.00		38.00		0.03	

Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?			yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?			yes	yes	yes

**Notes:** PSI = pounds per square inch  
 PSID = pounds per square inch difference (before filter - after filter)  
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

Lillie Hazelton  
 LEH  
 541 415-9788  
 CERT #:

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP : Takelma
Disinfection <i>Giardia</i> Log Inactiv: 0.5

System Name: Siskiyou Field Institute	ID#: 41	95360	Month/Year: Dec2025
---------------------------------------	---------	-------	---------------------

Date / Time	Minimum Cl2 Residual at 1st User ( C ) 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.4	70	35.0	11.3	8.60	30.6	YES	3.7
2	0.55	70	35.0	10.0	8.60	32.4	YES	3.7
3	0.55	70.95	35.5	9.9	8.80	35.1	YES	3.65
4	0.55	70.95	35.5	9.9	8.80	35.1	YES	3.65
5	0.55	70	35.0	12.0	8.80	30.4	YES	3.7
6	0.55	70.95	35.5	10.0	8.70	33.6	YES	3.65
7	0.55	70	35.0	9.9	8.70	33.8	YES	3.7
8	0.55	69.06	34.5	11.8	8.50	27.6	YES	3.75
9	0.55	69.06	34.5	11.8	8.50	27.6	YES	3.75
10	0.55	69.81	34.9	12.0	8.60	27.5	YES	3.71
11	0.55	69.81	34.9	12.0	8.60	33.8	YES	3.7
12	0.55	69.62	34.8	10.0	8.60	32.4	YES	3.72
13	0.55	70	35.0	9.6	8.60	33.3	YES	3.7
14	0.55	70.38	35.2	10.0	8.50	31.2	YES	3.68
15	0.55	70.38	35.2	10.0	8.50	31.2	YES	3.68
16	0.55	70	35.0	11.0	8.60	30.2	YES	3.7
17	0.55	69.62	34.8	10.0	8.60	32.4	YES	3.72
18	0.55	70	35.0	9.0	8.60	34.7	YES	3.7
19	0.55	70	35.0	9.0	8.60	34.7	YES	3.7
20	0.55	70.38	35.2	9.0	8.60	34.7	YES	3.68
21	0.55	71.94	36.0	9.1	8.60	34.4	YES	3.6
22	0.55	71.94	36.0	9.1	8.60	34.4	YES	3.6
23	0.55	70.38	35.2	9.0	8.60	34.7	YES	3.68
24	0.55	70	35.0	11.0	8.60	30.2	YES	3.7
25	0.55	70.38	35.2	10.0	8.60	32.4	YES	3.68
26	0.55	70.38	35.2	9.0	8.60	34.7	YES	3.68
27	0.55	70.38	35.2	9.0	8.60	34.7	YES	3.68
28	0.55	70.57	35.3	10.0	8.60	32.4	YES	3.67
29	0.55	70.57	35.3	9.0	8.60	34.7	YES	3.67
30	0.55	71.54	35.8	7.1	8.80	30.2	YES	3.62
31	0.55	71.94	36.0	8.0	8.70	34.4	YES	3.6

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022