

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Multnomah**

Cartridge or Bag Filtration with UV *Giardia*/*Crypto*/Viral Disinfection

Month/Year: **23-Sep**

System Name: **PAE Living Building Rain Harvest System** WS ID#: **41- 95690** WTP ID: _____

Change Filter at max PSID = **35 PSID** (see manufacturer's specification)

Day	Pressure Loss			Turbidity	
	PSI Before Filter	PSI After Filter	PSID	Compliance Turbidity [NTU]	Highest NTU of the day 1
1	OFF				
2	38.00	12.00	26.00	0.05	0.12
3	OFF				
4	OFF				
5	OFF				
6	OFF				
7	OFF				
8	38.00	12.00	26.00	0.04	0.11
9	OFF				
10	OFF				
11	38.00	12.00	26.00	0.04	0.14
12	OFF				
13	OFF				
14	36.00	12.00	24.00	0.04	0.15
15	OFF				
16	OFF				
17	OFF				
18	38.00	12.00	26.00	0.04	0.16
19	OFF				
20	OFF				
21	OFF				
22	38.00	13.00	25.00	0.05	0.13
23	OFF				
24	OFF				
25	38.00	13.00	25.00	0.04	0.12
26	OFF				
27	OFF				
28	OFF				
29	OFF				
30	OFF				
31	OFF				

Cartridge & Bag Filtration (circle Yes or No)

95% of daily turbidity readings \leq 1 NTU? Yes No

All daily turbidity readings \leq 5 NTU? Yes No

Monthly UV Summary (circle Yes or No)

Was the volume of off-spec water produced less than 5% for the month? Yes No

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)

PRINTED NAME: Dustin T. Thorson
DATE: September 9th, 2023

PHONE #: (503) 224-3454 **CERT #:** T- 323544 **SIGNATURE:** *Dustin T. Thorson*

¹ If one NTU value per day measured, value same as Compliance Turbidity. Intended for multiple readings per day. Used for optimization efforts or Highest NTU of the day is for optimization, not compliance. Highest is only for state-wide tracking of performance among all treatment systems.

OHA - Drinking Water Services - Surface Water Quality Data Form			County: Multnomah
Cartridge or Bag Filtration with UV <i>Giardia/Crypto/Viral</i> Disinfection			Month/Year: Jul-23
System Name: PAE Living Building Rain Harvest System	ID# 41- 95690	WTP ID:	

Minimum UVT during month: 112 % Duty sensor variation from reference sensor %: 0.11%
 Minimum Validated UVT: 77.50% Min. UV Dose achieved/intended this month: 8,678 / 186^{mJ}/cm²

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[mW/cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	OFF					
2	11	220	Y	662	0	-
3	OFF					
4	OFF					
5	OFF					
6	OFF					
7	OFF					
8	11	215	Y	766	0	-
9	OFF					
10	OFF					
11	11	220	Y	608	0	
12	OFF					
13	OFF					
14	11	216	Y	763	0	-
15	OFF					
16	OFF					
17	OFF					
18	11	220	Y	769	0	-
19	OFF					
20	OFF					
21	OFF					
22	11	215	Y	771	0	-
23	OFF					
24	OFF					
25	11	220	Y	642	0	-
26	OFF					
27	OFF					
28	OFF					
29	OFF					
30	OFF					
31	OFF					
Monthly Cumulative % Off-Spec Water Produced ²						

² If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350