

System Name: PAE Living Building Rain Harvest System WS ID#: 41- 95690 WTP ID: _____
 Change Filter at max PSID = 35 PSID (see manufacturer's specification)

Day	Pressure Loss			Turbidity	
	PSI Before Filter	PSI After Filter	PSID	Compliance Turbidity [NTU]	Highest NTU of the day 1
1	26	14	12	0.09	1.9
2	OFF				
3	OFF				
4	OFF				
5	OFF				
6	34	11	23	0.10	0.185
7	34	11	23	0.07	0.186
8	OFF				
9	OFF				
10	OFF				
11	OFF				
12	34	12	22	0.09	0.204
13	OFF				
14	OFF				
15	34	15	19	0.06	0.186
16	OFF				
17	OFF				
18	OFF				
19	36	13	23	0.09	0.452
20	OFF				
21	OFF				
22	38	14	24	0.13	0.948
23	OFF				
24	OFF				
25	OFF				
26	OFF				
27	OFF				
28	OFF				
29	OFF				
30	OFF				
31	OFF				

Cartridge & Bag Filtration (circle Yes or No)

95% of daily turbidity readings ≤ 1 NTU? Yes No
 All daily turbidity readings ≤ 5 NTU? Yes No

Monthly UV Summary (circle Yes or No)

Was the volume of off-spec water produced less than 5% for the month? Yes No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)

PRINTED NAME: Dustin T. Thorson
DATE: January 9th, 2024

PHONE #: (503) 224-3454 **CERT #:** T- 323544 **SIGNATURE:** *Dustin T. Thorson*

¹ If one NTU value per day measured, value same as Compliance Turbidity. Intended for multiple readings per day. Used for optimization efforts or Highest NTU of the day is for optimization, not compliance. Highest is only for state-wide tracking of performance among all treatment systems.

OHA - Drinking Water Services - Surface Water Quality Data Form	County: Multnomah
Cartridge or Bag Filtration with UV <i>Giardia/Crypto/Viral</i> Disinfection	Month/Year: Dec-22
System Name: PAE Living Building Rain Harvest System	ID# 41- 95690
	WTP ID:

Minimum UVT during month: 110 % Duty sensor variation from reference sensor %: 0.11%
 Minimum Validated UVT: 77.50% Min. UV Dose achieved/intended this month: 9,324/ 186^{mJ}/cm²

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[^{gpm} / _{unit}]	[^{mW} / _{cm2}]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	10	221	Y	332	0	
2	OFF					
3	OFF					
4	OFF					
5	OFF					
6	10	220	Y	522	0	
7	10	217	Y	567	0	
8	OFF					
9	OFF					
10	OFF					
11	OFF					
12	10	219	Y	752	0	
13	OFF					
14	OFF					
15	10	217	Y	789	0	
16	OFF					
17	OFF					
18	OFF					
19	10	216	Y	598	0	
20	OFF					
21	OFF					
22	10	210	Y	834	0	-
23	OFF					
24	OFF					
25	OFF					
26	OFF					-
27	OFF					
28	OFF					
29	OFF					
30	OFF					
31	OFF					
Monthly Cumulative % Off-Spec Water Produced ²						

² If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.
Return by 10th of following month by email, fax or mail to:
 dwp.dmce@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350