

OHA - Drinking Water Services - Surface Water Quality Data Form		County: Multnomah
Cartridge or Bag Filtration with UV <i>Giardia</i>/Crypto/Viral Disinfection		Month/Year: Nov. 2024
System Name: PAE Living Building Rain Harvest System	WS ID#: 41-	95690 WTP ID:

Change Filter at max PSID = 35 psi (see manufacturer's specification)

Day	Pressure Loss			Turbidity	
	PSI Before Filter	PSI After Filter	PSID	Compliance Turbidity [NTU]	Highest NTU of the day 1
1	22.00	15.00	7.00	0.06	0.22
2	Off				
3	Off				
4	Off				
5	14.00	11.00	3.00	0.08	0.22
6	Off				
7	20.00	14.00	6.00	0.07	0.22
8	22.00	14.00	8.00	0.19	0.22
9	Off				
10	Off				
11	Off				
12	20.00	15.00	5.00	0.20	0.23
13	Off				
14	Off				
15	21.00	14.00	7.00	0.11	0.24
16	Off				
17	Off				
18	Off				
19	21.00	14.00	7.00	0.06	0.25
20	Off				
21	Off				
22	22.00	14.00	8.00	0.06	0.025
23	Off				
24	Off				
25	Off				
26	23.00	14.00	9.00	0.19	0.26
27	Off				
28	Off				
29	22.00	14.00	8.00	0.10	0.26
30	Off				

95% of daily turbidity readings \leq 1 NTU?

☒ Yes ☐ No

All daily turbidity readings \leq 5 NTU?

☒ Yes ☐ No

Monthly UV Summary (circle Yes or No)

Was the volume of off-spec water produced less than 5% for the month?

☒ Yes ☐ No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PRINTED NAME: Dustin Thorson

DATE: 12/09/24

PHONE #: (503) 224-3454

CERT #: T-323544

SIGNATURE: 

¹ If one NTU value per day measured, value same as Compliance Turbidity. Intended for multiple readings per day. Used for optimization efforts or Highest NTU of the day is for optimization, not compliance. Highest is only for state-wide tracking of performance among all treatment systems.

OHA - Drinking Water Services - Surface Water Quality Data Form		County: Multnomah
Cartridge or Bag Filtration <u>with</u> UV <i>Giardia</i>/<i>Crypto</i>/Viral Disinfection		Month/Year: Nov. 2024
System Name: <u>PAE Living Building Rain Harvest System</u>	ID# 41- <u>95690</u>	WTP ID: _____

Minimum UVT during month: 99 % Duty sensor variation from reference sensor %: 0.11%
 Minimum Validated UVT: 77.50% Min. UV Dose achieved/intended this month: 7,568/ 186 mJ/cm²

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[mW/cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	10.8	190	Y	475	-	
2	Off					
3	Off					
4	Off					
5	11.1	189	Y	393	-	
6	Off					
7	10.7	191	Y	359	-	
8	11	191	Y	144	-	
9	Off					
10	Off					
11	Off					
12	10.8	191	Y	478	-	
13	Off					
14	Off					
15	10.7	190	Y	749	-	
16	Off					
17	Off					
18	Off					
19	10.9	190	Y	379	-	
20	Off					
21	Off					
22	11.2	190	Y	584	-	
23	Off					
24	Off					
25	Off					
26	10.9	191	Y	473	-	
27	Off					
28	Off					
29	10.8	195	Y	230	-	
30	Off					
Monthly Cumulative % Off-Spec Water Produced ²						-

² If ≥ 5% of total water produced is off-spec., notify DWS within 24 hours.

Return by 10th of following month by email, fax or mail to:
 dwp.dmce@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350